

Bid Document

Bid Details	
Bid End Date/Time	16-08-2021 17:00:00
Bid Opening Date/Time	16-08-2021 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	65 (Days)
Ministry/State Name	Chandigarh
Department Name	Municipal Corporation, Chandigarh
Organisation Name	N/a
Office Name	Chandigarh
Total Quantity	1
Item Category	Power Generator-DG Set (Upto 900 KVA)
Minimum Average Annual Turnover of the Bidder	6 Lakh (s)
OEM Average Turnover (Last 3 Years)	6 Lakh (s)
Years of Past Experience required	2 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	80 %
Bid to RA enabled	No
Time allowed for Technical Clarifications during technical evaluation	2 Days
Evaluation Method	Total value wise evaluation

EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	2.00
EMD Amount	25853

ePBG Detail

Advisory Bank	State Bank of India
ePBG Percentage(%)	5.00
Duration of ePBG required (Months).	14

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

COMMISSIONER

Municipal Corporation, Chandigarh.

(Commissioner, Mc Chandigarh)

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	No
-------------------------	----

MII Purchase Preference

MII Purchase Preference	No
-------------------------	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Power Generator-DG Set (Upto 900 KVA) (1 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	100
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase
ENGINE	Rated Engine Power (kWm)	110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxilary power Consumption by the Power generator) x Power factor(0.8) / Alternator effience Or higher
	Type of Engine cooling	Liquid Cooled
	Type of governer	Electronic Or higher
	Number of cylinders (nos)	4
	Rated RPM of Engine (RPM)	1500
	Fuel	High Speed Diesel (HSD)
	Starting voltage (volt)	12
	Salient Features of Engine	Turbo Charged Engine, Direct injection Fuel System
GOVERNING CLASS	"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	15
	"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	15.0
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	4.5
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	4

Specification	Specification Name	Bid Requirement (Allowed Values)
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	5.0
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5
ALTERNATOR	Alternator Voltage Rating	415.0
	Efficiency at rated Power factor at 75% of full Load	91.52 - 100.0 Or higher
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Voltage Regulation Grade	VG 3 Or higher
	Alternator IP Rating	IP 23 Or higher
	Salient features of Alternator	NA
CONTROL PANEL	Control Panel	AMF Control Panel
	Control Panel Location	Inside the canopy
	IP Rating of Control Panel	IP 53, IP 54, IP 55 Or higher
	Display meters in the control panel (with appropriate rating and accuracy class) - inclusive in the scope of supply	Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger
	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Powerfactor, Frequency, Fuel level, Event log, Control supply Voltage
	Indicators	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
	Audio Alarm	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
ACOUSTIC ENCLOSURE	Sheet Thickness(mm)	1.6, 1.8, 2 Or higher
	Thickness of insulation	40.0 - 120.0 Or higher
	Density of insulation (kg/cubic m)	28.0 - 100.0 Or higher
	Noise level at 1 meter (dB)	75

Specification	Specification Name	Bid Requirement (Allowed Values)
Fuel Tank	Fuel Tank Capacity	230.0
	Number of Fuel tank	1
	Fuel Tank Sheet Material Thickness(mm)	2, 3 Or higher
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load
BATTERY	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
	Battery capacity (Ah)	130
	No of batteries	1
SALIENT FEATURES	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0, 500, 1000, 2000 Or higher
	Number of Axlels	0
	Number of wheels	'NA' for without trailer
	Wheel Tyre size	0.0
	Brakes	NA for Fixed/Skid Mounted Power Generator, Hydraulic, Electrical Or higher
	Trailer Complying to CMVR act and Regulation	NA for Fixed/Skid Mounted Power Generator
	Salient Features of trailer	NA
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply Or higher
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.

Specification	Specification Name	Bid Requirement (Allowed Values)
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.

Specification	Specification Name	Bid Requirement (Allowed Values)
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICE S	Warranty on Complete power genertor/DG Set	24, 36 Or higher
	Warranty in running hours	5000.0 - 5000.0 Or higher
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibility)*	2
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB
	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ravi Sharma	160017,30 Bays building, sector 17 B Chandigarh	1	30

Buyer Added Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

2. **Nominated Inspection Agency:** On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC): Board of Officers nominated by Worthy CMC
Post Receipt Inspection at consignee site before acceptance of stores: Board of Officers nominated by Worthy CMC
3. Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address Slaughter House, Industrial Area, Phase-1, Chandigarh Slaughter House, Industrial Area, Phase-1, Chandigarh Slaughter House, Industrial Area, Phase-1, Chandigarh Slaughter House, Industrial Area, Phase-1, Chandigarh Slaughter House, Industrial Area, Phase-1, Chandigarh.
4. Bidders can also submit the EMD with Account Payee Demand Draft in favour of Commissioner, Municipal Corporation, Chandigarh payable at Chandigarh.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
5. **Bidder financial standing:** The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.
6. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
7. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
8. Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for 2 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.
9. Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.
10. **Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER):** Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.
When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.
11. Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of Commissioner, Municipal Corporation, Chandigarh A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.
12. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG).Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be

liable to re-imburse the cost of such service / rectification to the Buyer.

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---