## **Tour Report and CDA Claim**

	d a kick off meeting with the nodal an initial field survey under AMRUT	Date: 31.10.2017
TOUR REPORT		REF: AMRUT
Place : Khurja (UP)	NAME (S): 1. Tarun Kumar, Sr. Engineer  PERIOD: 27-09-2017 to 28-09-2017  MAIN PERSONS CONTACTED:	(2 Days)
	1. Mr. Navdeep Gupta, Junior Engine 2. Mr. Sachin Kumar, Junior Engine	

## **BRIEF SUMMARY:**

- EESL and PEPL representatives requested ULB members to provide electricity bills, cost of repair and maintenance, cost of operation and cost of purchase of new pumps/motor/accessories for the last three financial years (i.e. 2014-15, 2015-16 and 2016-17) for each pump month wise.
- ULB Members assured EESL and PEPL teams to provide all the required data as maximum as possible.
- ULB members informed EESL and PEPL representatives that they have 13 water pumps and 6 OHTs in actual and out of 13 pumps, 11 pumps are in running condition and rest 2 pumps are under maintenance since long.
- ULB also informed that almost all the water pumps operate approximately 8 hours per day due to lack of electricity supply in the city.
- EESL and PEPL representatives also requested ULB members for arranging one
  plumber/fitter during audit who will be responsible to install the pressure gauge in existing
  tapping points or on new tapping points.
- ULB agreed to provide a plumber for the audit and they deployed Mr. Abid (Plumber, ULB)
  with the auditing team at the same time.
- EESL, PEPL and ULB teams visited all the pumps for an initial field study and noticed that all the pumps are provided with tapping for chlorination dosing.
- ULB members informed EESL and PEPL that due continuous holidays, no member would be available from ULB team for the audit work so PEPL can start their audit work after 2nd of October 2017.

## **Details of CDA Claimed:**

No. of days (2)  $\times$  750 = Rs. 1500/-