

The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Climate and Environmental Health
Division of Environmental Health Regulations and Standards
67 Forest Street, Suite # 100
Marlborough, MA 01752
617-624-6000 | mass.gov/dph

Maura T. Healey
Governor

Kimberley Driscoll
Lieutenant Governor

Kiame Mahaniah, MD, MBA
Secretary

Robert Goldstein, MD, PhD
Commissioner

October 20, 2025

To: Shawn Jenkins, Commissioner, Department of Corrections (electronic copy)
Kiame Mahaniah, MD, MBA, Secretary, Executive Office of Health and Human Services (electronic copy)
Clerk, Massachusetts House of Representatives (electronic copy)
Clerk, Massachusetts Senate (electronic copy)
Lieutenant Jason Graham, Compliance Officer (electronic copy)


Greetings,

Pursuant to 105 CMR 451.403, please find the inspection report for Hampshire County Jail and House of Correction, Pre-Release Center, the Plan of Correction (POC) from the facility and the POC acceptance letter from the Division of Environmental Health Regulations and Standards (EHRS).

Sincerely,

Thomas Murphy
Environmental Analyst, EHRS, BCEH

Cc: Robert Goldstein, MD, PhD, Commissioner, DPH (electronic copy)
Terrence Reidy, Secretary, Executive Office of Public Safety and Security (electronic copy)
Merridith O'Leary, Commissioner, Northampton Health and Human Services (electronic copy)
Brianna Arruda, Director, Policy Development and Compliance Unit (electronic copy)
Glenn Sexton, Superintendent (electronic copy)



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Climate and Environmental Health
Division of Environmental Health Regulations and Standards
67 Forest Street, Suite # 100 Marlborough, MA 01752
617-624-6000 | mass.gov/dph

Maura T. Healey
Governor

Kimberley Driscoll
Lieutenant Governor

Kiame Mahaniah, MD, MBA
Secretary

Robert Goldstein, MD, PhD
Commissioner

October 10, 2025

Patrick J. Cahillane, Sheriff
Hampshire County Jail and House of Correction
205 Rocky Hill Road
Northampton, MA 01060 (electronic copy)

Re: Facility Inspection – Hampshire County Jail and House of Correction, Pre-Release Center, Northampton

The Massachusetts Department of Public Health (Department) Division of Environmental Health Regulations and Standards (EHRS) conducted an inspection of the Hampshire County Jail and House of Correction on October 8, 2025 accompanied by Lieutenant Jason Graham, Compliance Officer, and Lieutenant Bryan Luszczy, in accordance with Department regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities.

The inspection identified 1 total deficiency: 1 repeat deficiency under the Recommended Standards (.300 series).

Overview

Section 1 provides details of all deficiencies, including repeat deficiencies, found during the inspection. These are categorized by Required Standards, Recommended Standards, or additional applicable regulatory standards.

Section 2 provides information on areas that EHRS found to be compliant.

Section 3 documents the areas that EHRS did not inspect.

Section 4 provides information on submitting a Plan of Correction for the identified deficiencies.

Section 5 outlines observations and recommendations related to the inspection.

SECTION 1: Health and Safety Deficiencies

Deficiencies under the Recommended Standards (.300 series)

1 repeat deficiency (indicated by an *) was found during the inspection:

1. Pre-release Housing	Laundry Room	105 CMR 451.353*	Interior Maintenance: Baseboard heater missing
------------------------	--------------	------------------	--

SECTION 2: Areas Found to be in Compliance

EHRS inspected 28 additional areas of the facility which were found to be in compliance.

Section 3: Areas EHRS did not inspect

EHRS did not inspect 3 areas of the facility because they were either in use, locked, or under construction:

1. Administration Building	Right Office	Unable to Inspect – Locked
2. Administration Building	Left Office	Unable to Inspect – Locked
3. Administration Building	Tool Shed	Unable to Inspect – Locked

SECTION 4: Plan of Correction

This facility does not comply with the Department's regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice which includes:

1. Specific corrective steps to be taken
2. A timetable for the corrective actions for larger projects
3. The date by which correction will be achieved
4. Any interim measures being implemented to ensure the health and safety of incarcerated individuals and facility staff
5. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

SECTION 5: Observations and Recommendations

1. The inmate population was 8 at the time of inspection.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" [105 CMR 451.000](#) available in both PDF and RTF formats. For more specific information about the food standards, you can download the merged food code, which can be found [here](#).

An inspection may also include observations of other conditions which could constitute a threat to the health or safety of inmates or employees, including but not limited to the standards set forth by the Department as follows, and report on such pursuant to 451.402(B). You can use these links below to review these standards:

- [105 CMR 205.000](#): Minimum Standards Governing Medical Records and Conduct of Physical Examinations in Correctional Facilities
- [105 CMR 480.000](#): Minimum requirements for the Management of Medical or Biological Waste
- [105 CMR 500.000](#): Good Manufacturing Practices for Food

This inspection report is true and accurate to the best of my knowledge.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Thomas Murphy', is written over a faint, light blue rectangular background.

Thomas Murphy
Environmental Analyst, EHRS, BCEH



THE COMMONWEALTH OF MASSACHUSETTS

Hampshire Sheriff's Office Jail & House of Correction

P.O. Box 7000
205 Rocky Hill Road
Northampton, Massachusetts 01061-7000



Sheriff

PATRICK J. CAHILLANE

Superintendent

GLEN N. SEXTON

TELEPHONE

(413) 584-5911

FAX

(413)-584-2695

October 14th, 2025


Mr. Thomas Murphy
Environmental Analyst, CSP, BEH
Commonwealth of Massachusetts
Executive Office Health & Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
23 Service Center Road
Northampton, MA 01060

Re: Hampshire County Jail & HOC Inspection dated October 10th, 2025

Dear Mr. Murphy,

At your request the following items have been addressed, please refer to the enclosed documentation for the corrective actions that have been taken.

Sincerely yours,



Patrick J. Cahillane
Sheriff

SECTION 1: Health and Safety Deficiencies

Deficiencies under the Recommended Standards (.300 series)

1 repeat deficiency (indicated by an *) was found during the inspection:

1. Pre-release Housing	Laundry Room	105 CMR 451.353*	Interior Maintenance: Baseboard heater missing <u>Request for baseboard heater submitted to landlord</u> <u>expected date for repair 12/11/25</u>
---------------------------	--------------	------------------	---



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Climate and Environmental Health
Division of Environmental Health Regulations and Standards
67 Forest Street, Suite # 100
Marlborough, MA 01752
617-624-6000 | mass.gov/dph

Maura T. Healey
Governor

Kimberley Driscoll
Lieutenant Governor

Kiame Mahaniah, MD, MBA
Secretary

Robert Goldstein, MD, PhD
Commissioner

October 17, 2025

Patrick J. Cahillane, Sheriff
Hampshire County Jail and House of Correction
205 Rocky Hill Road
Northampton, MA 01060 (electronic copy)

Re: Plan of Correction - Hampshire County Jail and House of Correction, Pre-Release Center, Northampton

Dear Sheriff Cahillane:

The Massachusetts Department of Public Health, Division of Environmental Health Regulations and Standards (EHRS) has received your Plan of Correction in response to an inspection on October 8, 2025. After review, the EHRS finds the plan addresses all the deficiencies noted.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address listed above.

Sincerely,

A handwritten signature in blue ink, appearing to read "Thomas Murphy".

Thomas Murphy
Environmental Analyst, EHRS, BCEH

cc: Glenn Sexton, Superintendent
Lieutenant Jason Graham, Compliance Officer

(electronic copy)
(electronic copy)