

PMSTPCOL PEmails

From: Tai, Tom
Sent: Thursday, June 11, 2009 10:38 AM
To: John Price (jeprice@stpegs.com)
Cc: STPCOL
Subject: Draft RAI 2960 for Chapter 3.5.1.3
Attachments: RAI 2960 03.05.01-xx.doc

John,

Please review the attached RAI (03.05.01.03-xx) for Chapter 3.5.1. If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNOC.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1299

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71FBAC49B5D)

Subject: Draft RAI 2960 for Chapter 3.5.1.3
Sent Date: 6/11/2009 10:37:41 AM
Received Date: 6/11/2009 10:37:42 AM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"John Price (jeprice@stpegs.com)" <jeprice@stpegs.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	386	6/11/2009 10:37:42 AM
RAI 2960 03.05.01-xx.doc		29178

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2960 Revision 02

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 03.05.01.03 - Turbine Missiles
Application Section: 3.5.1.3

QUESTIONS for Component Integrity, Performance, and Testing Branch 2 (ESBWR/ABWR Projects)
(CIB2)

03.05.01.03-***

Subsection 3.5.1.1.1.3 of the ABWR DCD states that the COL applicant will submit for NRC approval, within three years of obtaining an operating license, a turbine system maintenance program including probability calculations of turbine missile generation based on the NRC approved methodology, or the COL applicant will volumetrically inspect all low pressure turbine rotors at the second refueling outage and every other (alternate) refueling outage thereafter until a maintenance program is approved by the staff. The staff reviewed COL License information item 3.5.4.5 in the STP COL, it states that "A turbine system maintenance program will be made available for NRC review prior to fuel load that includes a probability calculation of turbine missile generation and shows that the turbine meets the minimum requirements in Table 3.5-1. (COM 3.5-1)"

Please revise the submittal timeline for these two items from "prior to fuel load" to "within three years of obtaining an operating license."