Thenpennai Zone Fire Safety Office

Chengalpattu District, Tamil Nadu, India

Fire Safety No Objection Certificate

Reference Number	FS/NOC/2026/CGL/00418
Date of Issue	15 June 2026 (15/06/2026, DD/MM/YYYY)
Valid Until	14 June 2027 (14/06/2027, DD/MM/YYYY)
Institution Name	Palar Crest Engineering College
Campus Address	Survey No. 212/3, Palar Bank Road, Karungali Village, Chengalpattu District, Tamil Nadu 603 301, India
Buildings Covered	Block A (Academic); Block B (Academic); Block F (Laboratories); Hostel Block 1; Central Library
Date of Inspection	02 June 2026 (02/06/2026, DD/MM/YYYY)
Issuing Office	Thenpennai Zone Fire Safety Office

To
The Principal, Palar Crest Engineering College, Karungali Village, Chengalpattu District.

Subject: Fire safety no objection for the buildings of Palar Crest Engineering College — reg.

With reference to the application submitted by the institution and the inspection of the premises carried out on 02 June 2026, this office has no objection, from the fire safety point of view, to the continued use of the buildings listed above for educational and hostel purposes. This certificate is issued with reference number FS/NOC/2026/CGL/00418 on 15 June 2026 and remains valid until 14 June 2027, subject to the conditions set out below.

Conditions

1. Portable fire extinguishers shall be provided on every floor, kept in working order, and serviced at the intervals shown on their tags.
2. The fire alarm and detection system shall be tested at least once a month and each test entered in a fire register kept at the estate office.
3. Escape routes, staircases and the access lane around the buildings shall be kept free of obstruction at all times.
4. Exit signs and emergency lighting shall be maintained in working condition in all staircases and corridors.
5. An evacuation drill shall be held at least once every six months and the date recorded in the fire register.
6. Any change in the use, height or floor area of the buildings shall be reported to this office before work begins.
7. This certificate shall be renewed before 14 June 2027 (14/06/2027). It does not exempt the institution from any other approval required by law.

Place: Chengalpattu
Date: 15 June 2026 (15/06/2026)

Issuing Authority
Thenpennai Zone Fire Safety Office

Signature: not supplied on this copy

SYNTHETIC TEST DOCUMENT — NOT AN OFFICIAL CERTIFICATE