LaBTECH


WORKSHEET
ULTRASONIC LOGGING TESTING

FST03-FDT-D6760-2-260417

Customer		Report No.	
Project		Work Order No.	
		Test Method	
Location		Date Test	
Contractor			

Description of the pile/element:									
Pile No.*					Size *	m			
Type *					Pile head	soil			
Cut-off level *	mPD				Date installed *				
Pile Base level *	mPD				Ground level *	mPD			
Length *	m				New / retest				
Water temp	Tube 1	°C	Tube 2	°C	Water temp	Tube 3	°C	Tube 4	°C
Water temp	Tube 5	°C	Tube 6	°C	Sonic Tester ID				
Measuring Tape ID		Temp. Sensor ID			Probe (Tran./Race.) ID				

Tube Ref.	Tube Size(mm)	Tube Top Level(mPD)	Calculated Length(m)	Measured Length(m)	Difference(m)	Remaek
1						
2						
3						
4						
5						
6						

Trace	Tube Separation(m)	(A) Scanned Length (m)	(B) (2)Plumbed Length(m)	(1)Difference.A-B (m)	Tube Layout and Orientation
1-2					
1-3					
1-4					
1-5					
1-6					
2-3					
2-4					
2-5					
2-6					
3-4					
3-5					
3-6					
4-5					
4-6					
5-6					

Comment:
Description of Pile (If any):
Note: (1) Different between (A) & (B) shall be <0.25m OR <1% of (B) whichever is greater
(2) Plumbed Length is the shorted length between tube to and bottom of two tubes - 0.3m

*information provided by customer

Tested By (Operator)		Signature	
Checked By (Authorised Signature)		Signature	