WORKSHEET FST05-GTT-C939-2-260417

Flow of Grout for Preplaced-Aggregate Concrete (Flow Cone Method)

Test Method : ASTM C939M - 22 Job Reference No : _____

Information Supplied by Client

Client : _____

Project : _____

Test Location : _____ Contract No : _____

Batch No : _____ Works order No : _____

Location in Work : _____

Sample identification No : _____

Sample Informaion

Brand of Cement : _____ Quantity : _____

Brand of admixture : _____ Quantity : _____

Water : _____ Quantity : _____

Water / Cement Ratio : _____

Ambient Temperature : _____

Water Temperature : _____

Date of Testing : _____

Location:				
Time of Water Added:				
Time of Drawing Grout from the Mixer:				
Thermometer ID:	Flow Cone ID:		Timer ID:	
Test 1	Temperature of Specimen(˚C)			
	Time of Test			
	Time of Efflux of Grout (s)			
Test 2	Temperature of Specimen(˚C)			
	Time of Test			
	Time of Efflux of Grout (s)			
Average Time of Efflux (s)				
Different Time of Efflux to Average (s) *Note (2)				
Time to efflux compliance with standard		Yes / No	Yes / No	Yes / No
Time different compliance with standard		Yes / No	Yes / No	Yes / No

Note: (1) This test method is intended for used with grout having an efflux time of 35 s or less.
(2) Two tests having time of efflux within 1.8s of their average

Remark: _____

Tested By : _____ Checked By : _____

Date: : _____ Date: : _____