



CÓDIGO DE CABLEADO / WIRING CODE							
①	1-12 AWG (F) 1-12 AWG (N) 1-12 AWG (T) 1T-16mm	②	2-12 AWG (F) 2-12 AWG (N) 1-12 AWG (T) 1T-16mm	③	1-12 AWG (R) 1-12 AWG (R) 1-12 AWG (T) 1T-16mm	④	2-12 AWG (F) 2-12 AWG (N) 1-12 AWG (R) 1-12 AWG (T) 1T-16mm
				⑤	1-12 AWG (F) 1-12 AWG (N) 1-12 AWG (R) 1-12 AWG (T) 1T-16mm	⑥	1-10 AWG (F) 1-10 AWG (N) 1-12 AWG (T) 1T-16mm
⑦	1-12 AWG (F) 2-12 AWG (N) 1-12 AWG (R) 1-12 AWG (T) 1T-16mm	NOMENCLATURA / NOMENCLATURE (F)= CONDUCTOR DE FASE / PHASE CONDUCTOR (N)= CONDUCTOR NEUTRO / NEUTRAL CONDUCTOR (T)= CONDUCTOR DE TIERRA/ GROUND CONDUCTOR (R)=RETORNO / RETURN T= TUBERÍA CONDUTIT/ CONDUIT					

- (F) CONDUCTOR DE FASE O LINEA
(N) CONDUCTOR DE NEUTRO
(R) CONDUCTOR DE RETORNO
(T) CONDUCTOR DE TIERRA
(TA) CONDUCTOR DE TIERRA AISLADA
(C) CONDUCTOR DE CONTROL

- 0/27TV
AFÉ.NARANJA, AMARILLO) / (BROWN, ORANGE, YELLOW)
FASE A, FASE B, FASE C / PHASE A, PHASE B, PHASE C
0/12TV
EGRO, ROJO, AZUL) / (BLACK, RED, BLUE)
FASE A, FASE B, FASE C / PHASE A, PHASE B, PHASE C
GRIS / GRAY (27TV).
BLANCO / WHITE (27TV).
VERDE / GREEN

- (F) PHASE OR LIVE CONDUCTOR
(N) NEUTRAL CONDUCTOR
(R) RETURN CONDUCTOR
(T) GROUND CONDUCTOR
(TA) ISOLATED GROUND CONDUCTOR
(C) CONTROL CONDUCTOR

RESPONSABLE DEL PROYECTO

ING. JAVIER NUÑEZ MARMOLEJO
CEDULA PROFESIONAL: 5814603

