


CÓDIGO DE CABLEADO / WIRING CODE					
①	1-12 AWG (F) 1-12 AWG (N) 1-12 AWG (T) 1T-16mm	②	3-12 AWG (R) 3-12 AWG (N) 1-12 AWG (T) 1T-16mm	③	1-12 AWG (R) 1-12 AWG (N) 1-12 AWG (T) 1T-16mm
NOMENCLATURA / NOMENCLATURE (F)= CONDUCTOR DE FASE / PHASE CONDUCTOR (N)= CONDUCTOR NEUTRO / NEUTRAL CONDUCTOR (T)= CONDUCTOR DE TIERRA / GROUND CONDUCTOR (R)=RETORNO / RETURN T= TUBERIA CONDUIT/ CONDUIT					

7	NOMENCLATURA - CODIGOS DE CABEADOS. NOMENCLATURE - WIRING CODE. <table> <tr> <td>(F) CONDUCTOR DE FASE O LINEA</td> <td>(F) PHASE OR LIVE CONDUCTOR</td> </tr> <tr> <td>(N) CONDUCTOR DE NEUTRO</td> <td>(N) NEUTRAL CONDUCTOR</td> </tr> <tr> <td>(R) CONDUCTOR DE RETORNO</td> <td>(R) RETURN CONDUCTOR</td> </tr> <tr> <td>(T) CONDUCTOR DE TIERRA</td> <td>(T) GROUND CONDUCTOR</td> </tr> <tr> <td>(TA) CONDUCTOR DE TIERRA AISLADA</td> <td>(TA) ISOLATED GROUND CONDUCTOR</td> </tr> <tr> <td>(C) CONDUCTOR DE CONTROL</td> <td>(C) CONTROL CONDUCTOR</td> </tr> </table>	(F) CONDUCTOR DE FASE O LINEA	(F) PHASE OR LIVE CONDUCTOR	(N) CONDUCTOR DE NEUTRO	(N) NEUTRAL CONDUCTOR	(R) CONDUCTOR DE RETORNO	(R) RETURN CONDUCTOR	(T) CONDUCTOR DE TIERRA	(T) GROUND CONDUCTOR	(TA) CONDUCTOR DE TIERRA AISLADA	(TA) ISOLATED GROUND CONDUCTOR	(C) CONDUCTOR DE CONTROL	(C) CONTROL CONDUCTOR
(F) CONDUCTOR DE FASE O LINEA	(F) PHASE OR LIVE CONDUCTOR												
(N) CONDUCTOR DE NEUTRO	(N) NEUTRAL CONDUCTOR												
(R) CONDUCTOR DE RETORNO	(R) RETURN CONDUCTOR												
(T) CONDUCTOR DE TIERRA	(T) GROUND CONDUCTOR												
(TA) CONDUCTOR DE TIERRA AISLADA	(TA) ISOLATED GROUND CONDUCTOR												
(C) CONDUCTOR DE CONTROL	(C) CONTROL CONDUCTOR												



RESPONSABLE DEL PROYECTO

ING. JAVIER NUÑEZ MARMOLEJO
CEDULA PROFESIONAL: 5814603



Número Revisión Revision Number:	
------------------------------------	--