



TEST REPORT

NAME: POLE MOUNTED TRANSFORMER

TYPE/MODEL: DL-75/14.4/0.24

SERIAL NO.: 2604023-46

DATE: 2026/06/10

www.jiezoupower.com

Test report

POLE MOUNTED TRANSFORMER

Technical Proposal

DL-75-14.4-0.24

Series No. 2604023-46

Rated capacity(kVA)	75	Rated voltage	HV (kV)	LV(kV)	Rated current (A)		HV	LV
Method of cooling	ONAN		14.4	0.24			5.208	312.50
POLARITY	Subtractive polarity	Frequency (Hz)	60	Tap range of HV (kV)		14.4	14.4/13.8/13.2/12.87/12.54	
Insulation level (KV)	HV-LI		150/50		LV-LI		30/10	

Ratio and Polarity tests

Switch tap position	Voltage (kV)		Transformati on ratio	H1-H2 X3-X2	deviation (%)	H1-H2 X3-X1	deviation (%)
	HV Winding	LV Winding					
1	14.4000	0.24	60.0000	/	/	60.034	0.06
2	13.8000		57.5000	/	/	57.528	0.05
3	13.2000		55.0000	/	/	55.028	0.05
4	12.8700		53.6250	/	/	53.661	0.07
5	12.5400		52.2500	/	/	52.294	0.08
				H1-H2 X2-X1	deviation (%)	POLARITY	
1	14.40	0.12	120.000	120.080	0.07	Subtractive polarity	

Resistance measurements

Temperature: 27°C

Switch tap position	HV Winding (Ω)
	H1-H2
1	8.653
2	8.328
3	7.855
4	7.663
5	7.459

LV Winding (mΩ)		
X3-X1	X3-X2	X2-X1
2.200	1.4558	0.9514

Dielectric tests

Testing position	Insulation resistance	Applied withstand voltage t=60s	Induction withstand voltage t=36s	
	R60(MΩ)	Voltage (kV)	Applied voltage LV(kV)	0.48
H.V.~L.V. & Earth	>2500	50	Applied voltage HV(kV)	28.8
L.V.~H.V.& Earth	>2500	10	Frequency (Hz)	200

No-load losses, excitation current, Impedance voltage and load loss tests

No-load loss current I ₀ (%)	No-load loss P ₀ (W)	load loss P _K (W)(85°C)	Impedance voltage U _K (%)(85°C)	Efficiency
0.26	166.01	581.0	1.90	99.19%

Insulating oil and sealing test

Insulating oil testing		Seal test (compressed dry air method)			
Dielectric loss factor (90°C)	Oil breakdown voltage (KV)	Applied Pressure (kPa)	Duration	Residual pressure (kPa)	Result
/	/	30	24H	30	No leakage and damage

The test results meet the requirements of ANSI/IEEE C57.12 series standard and manufacture's technical specification



Test staff: B.B.Song

2026/06/10

Test company: JZPE POWER TRANSFORMER(JIANGSU)CO.,LTD.

Add:Longxi Industrial Zone,JiangYan District,Taizhou City,Jiangsu Province China

www.jiezoupower.com