



TEST REPORT

NAME: Three phase Substation Tranformer TYPE

MODEL: SL-5000/24.94/4.16

SERIAL NO.: 2511004

DATE: 2025/11/03

www.jiezoupower.com

Test report

Technical Proposal

Model

5000KVA transformer

Series No.

2511004

Rated capacity(KVA)	5000	Rated voltage	HV (KV)	LV(KV)	Rated current (A)		HV	LV
Method of cooling	ONAN		24.94	4.16			115.75	693.93
Vector group	Dyn1	Frequency (Hz)	60	Tape range of HV (%)		24.94	± 2*2.5%	
Insulation level (KV)	HV-LI	40			LV-LI		19	

Voltage ratio measurement and connection group label verification

Switch tap position	Voltage (V)		Transformation ratio	Measurement deviation (%)			Vector group
	HV Winding	LV Winding		AB/ab	BC/bc	CA/ca	
1	26187	4160	6.295	-0.04	-0.03	-0.03	Dyn1
2	25564		6.145	0.05	0.06	0.06	
3	24940		5.995	-0.00	-0.00	0.00	
4	24317		5.845	-0.05	-0.05	-0.05	
5	23693		5.695	0.04	0.05	0.05	

DC Resistance

Temperature : 20.5℃

Switch tap position	HV Winding (Ω)			Imbalance rate (%)	LV Winding (Ω)			Imbalance rate (%)
	H1H2	H2H3	H3H1		X1X2	X2X3	X3X1	
1	0.7438	0.7451	0.7435	0.22	0.015701	0.015623	0.015691	0.50
2	0.7253	0.7264	0.7250	0.19				
3	0.7051	0.7063	0.7049	0.20	X1X0	X2X0	X3X0	
4	0.6853	0.6865	0.6851	0.20	0.0080520	0.0079840	0.0079160	1.70
5	0.6664	0.6676	0.6662	0.21				

Insulation resistance

Testing position	Insulation resistance	Applied withstand voltage t=60s		Induction withstand voltage t=40s	
	R60(MΩ)	Voltage (KV)		Applied voltage LV(KV)	8.32
H.V.~L.V. & Earth	>2500	40		Applied voltage HV(KV)	49.88
L.V.~H.V.& Earth	>2500	19		Frequency (Hz)	180
H.V. & L.V.~Earth	>2500	/			

No-load loss and load loss

No-load loss current I ₀ (%)	No-load loss P ₀ (KW)	load loss P _k (KW)(85℃)	Impedance voltage U _k (%)(85℃)
0.10	3.409	31.421	5.66

Insulating oil and sealing test

Insulating oil testing		Seal test (compressed dry air method)			
Dielectric loss factor(%) (90℃)	Oil breakdown voltage (KV)	Applied Pressure (kPa)	Duration	Residual pressure (kPa)	Result
0.133	56.2	50	12H	50	No leakage and damage

The test results meet the requirements of IEEE C57.12.36 series standard and manufacture's technical specification.

Test staff: G.B.Song

Date: 2025/11/3

Test company: JZPE POWER TRANSFORMER(JIANGSU)CO.,LTD.

Add:Longxi Industrial Zone,JiangYan District,Taizhou City,Jiangsu Province China

www.jiezouppower.com