

75kva-3150kva Pad mounted transformer						
Rated Capacity(kVA)	High Voltage(v)	Low Voltage(v)	Connection Symbol	Standard	Short-circuit impedance(%)	Efficiency (%)
75	4160 7200 12000 12470 13200 13800 19920 24940 34500	110 220 230 400 480	Delta-Wye Dyn1 Ynyn0	IEEE/ANSI / DOE	4-7%	99.03
112.5						99.11
150						99.16
225						99.23
300						99.27
500						99.35
750						99.40
1000						99.43
1500						99.48
2000						99.51
2500						99.53
3150						

10kva-500kva Single phase pad/pole mounted transformer						
Rated Cap acity(kVA)	High Voltage(kv)	Low Voltage (kv)	Connection Symbol	Standard	Short-circuit impedance(%)	Efficiency (%)
10	4160 7200 12000 12470 13200 13800 19920 24940 34500	110 220 230 400 480	II0,II6	IEEE/ANSI / DOE	1.8-4%	98.70
15						98.82
25						98.95
37.5						99.05
50						99.11
75						99.19
100						99.25
167						99.33
250						99.39
333						99.43
500						99.49

Liquid-Immersed Distribution Transformers			
The efficiency of a liquid-immersed distribution manufactured on or after January 1,2016,shall be no less than that required for their KVA Rating in the table below.Liquid-immersed distribution transformers with kVA ratings minimum efficiency level determined by linear interpolation of the kva and efficiency values immediately above and below that kVA rating.			
single-phase		Three-phase	
KVA	Efficiency(%)	KVA	Efficiency(%)
10	98.7	15	98.65
15	98.82	30	98.83
25	98.95	45	98.92
37.5	99.05	75	99.03
50	99.11	112.5	99.11
75	99.19	150	99.16
100	99.25	225	99.23
167	99.33	300	99.27
250	99.39	500	99.35
333	99.43	750	99.4
500	99.49	1000	99.43
667	99.52	1500	99.48
833	99.55	2000	99.51
		2500	99.53

Note:All efficiency values are at 50 percent of nameplate-rated load,determined according to the DOE Test Method for measuring the Energy Consumption of Distribution Transformers under Appendix A Subpart K of 10CFR part 431