

Certificate of Compliance

Certificate Number:

UL-US-2444286-0

Report Reference:

E541627-20240919

Issue Date:

2024-11-11

Issued to:

JZPE POWER TRANSFORMER (JIANGSU) CO., LTD.
No.79, West 17 Group, Jintan Village, Yuxi Town, Jiangyan
District, Taizhou City, Jiangsu Province, China Taizhou, Js
225500
China

This certificate confirms that representative samples of:

XPLH - Transformers, Distribution, Liquid-filled Type, Over 600
Volts

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

IEEE C57.12.00, 1st Ed., Issue Date: 2021-11-09, IEEE C57.12.28,
Issue Date 2023-12-06

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2444286-0
Report reference E541627-20240919
Date 2024-11-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
ZGSABC-DE-XXXX/YY.YYY/Z.ZZZ, where ZG represents Pad-mounted transformer, S represents three phases, A represents insulation oil type, may be blank or R, blank represents mineral oil, R represents less-flammable vegetable oil. B represents winding material, L represents aluminum. C represents core material, blank represents electrical grade steel. D represents primary connection, may be H or Z, H represents loop, Z represents radial. E represents bushing type, blank represents dead front. XXXX represents rate capacity, for UL may be 45~5000 represents 45~ 5000 KVA, for CUL may be 75~ 3000 represents 75~3000 KVA. "YY.YYY" represents high voltage, for UL may be 20.78 represents 20780 Grd Y/12 000, 22.86 represents 22860 Grd Y/13200 Vac, 23 represents 23 000 Δ Vac, 23.9 represents 23900 Grd Y/13800 Vac, 24(12) represents 24000(12000)Grd Y/13860(6930) or 24000(12000)ΔVac, 24.94 represents 24940 Grd Y/14400 Vac or 24940ΔVac, 24.94(12.47)represents 24940(12470)GrdY/14400(7200) Vac or 24.94(12.47)ΔVac , 26.4(13.2)represents 26400(13200)GrdY/14400(7200) Vac, 27.6(13.8)represents 27600(13800)GrdY/14400(7200) Vac, for CUL may be 24.94 represents 24940 Grd Y/14400 Vac, 24.94(12.47)represents 24940(12470)GrdY/14400(7200) Vac, 27.6 represents 27600GrdY/15935 Vac, 27.6(13.8)represents 27600(13800)GrdY/14400(7200) Vac. /Z.ZZZ is optional, "Z.ZZZ" represents the low voltage, may be 0.208 represents 208Y/120 Vac, 0.24 represents 240 Vac, 0.415 represents 415 or 415Y/240Vac, 0.480 represents 480 or 480Y/277Vac, 0.600 represents 600 or 600Y/347 Vac. (X or Y or Z may be blank).	Three phase Distribution, Liquid-Immersed Pad-Mounted Transformers



David Picuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-2433474-0

Report Reference:

E541627-20240919

Issue Date:

2024-11-11

Issued to:

**JZPE POWER TRANSFORMER (JIANGSU) CO., LTD.
No.79, West 17 Group, Jintan Village, Yuxi Town, Jiangyan
District, Taizhou City, Jiangsu Province, China Taizhou, Js
225500
China**

This certificate confirms that representative samples of:

**XPLH7 - Transformers, Distribution, Liquid-filled Type, Over 750
Volts Certified for Canada**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C227.4, 3rd Ed., Issue Date: 2021-03-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2433474-0
Report reference E541627-20240919
Date 2024-11-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
ZGSABC-DE-XXXX/YY.YYY/Z.ZZZ, where ZG represents Pad-mounted transformer, S represents three phases, A represents insulation oil type, may be blank or R, blank represents mineral oil, R represents less-flammable vegetable oil. B represents winding material, L represents aluminum. C represents core material, blank represents electrical grade steel. D represents primary connection, may be H or Z, H represents loop, Z represents radial. E represents bushing type, blank represents dead front. XXXX represents rate capacity, for UL may be 45~5000 represents 45~ 5000 KVA, for CUL may be 75~ 3000 represents 75~3000 KVA. "YY.YYY" represents high voltage, for UL may be 20.78 represents 20780 Grd Y/12 000, 22.86 represents 22860 Grd Y/13200 Vac, 23 represents 23 000 Δ Vac, 23.9 represents 23900 Grd Y/13800 Vac, 24(12) represents 24000(12000)Grd Y/13860(6930) or 24000(12000)ΔVac, 24.94 represents 24940 Grd Y/14400 Vac or 24940ΔVac, 24.94(12.47)represents 24940(12470)GrdY/14400(7200) Vac or 24.94(12.47)ΔVac, 26.4(13.2)represents 26400(13200)GrdY/14400(7200) Vac, 27.6(13.8)represents 27600(13800)GrdY/14400(7200) Vac, for CUL may be 24.94 represents 24940 Grd Y/14400 Vac, 24.94(12.47)represents 24940(12470)GrdY/14400(7200) Vac, 27.6 represents 27600GrdY/15935 Vac, 27.6(13.8)represents 27600(13800)GrdY/14400(7200) Vac. /Z.ZZZ is optional, "Z.ZZZ" represents the low voltage, may be 0.208 represents 208Y/120 Vac, 0.24 represents 240 Vac, 0.415 represents 415 or 415Y/240Vac, 0.480 represents 480 or 480Y/277Vac, 0.600 represents 600 or 600Y/347 Vac. (X or Y or Z may be blank).	Three phase Distribution, Liquid-Immersed Pad-Mounted Transformers



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

