







Diagram for connect

DATE SHEET	
RATING	150KVA
PRIMARY VOLTAGE(V)	13800 V DELTA
SECONDARY VOLTAGE(V)	208Y/120 V
FREQUENCY	60Hz
VECTOR GROUP	Dyn1
TAP CHANGER	$\pm 2 \times 2.5\%$
CONDUCTOR	AL
PRIMARY VOLTAGE LI/AC	95/34KV
SECONDARY VOLTAGE LI/AC	30/10KV
INSULATING OIL	Mineral Oil
TEMPERATURE RISE	65°C/65°C
LOAD LOSS AT RATED VOLTAGE	1350W
NO LOAD LOSSES	330W
IMPEDANCE	$\geq 1.5\%$
ALTITUDE	$\leq 1000m$
COLOR	ANSI 70#


ITEM	WEIGHT
CORE & COIL WEIGHT	1645LBS
OIL VOLUME	112GAL
TOTAL MASS	2873LBS

No.	DESCRIPTION	QTY	MODEL
16	NO-LOAD TAP CHANGER	1	WSLI12 63/20-6*5
15	GROUND STRAP	1	
14	INSULATING OIL	1	
13	GROUND STRAP	1	
12	LV BUSHING	4	ANSI-1.2/600
11	HV BUSHING	3	ANSI-15/55A
10	FASTENING RING	1	
9	SUPPORT LUG	1	
8	SUPPORT LUG	1	
7	LIFTING LUG	2	
6	NAMEPLATE	1	
5	KVA MARK	1	
4	GROUND TERMINAL	1	
3	PREESURE RELIEF DEVICE	1	YSF-0.03
2	TANK COVER	1	
1	CORE&COIL	1	

TYPE					DWG. NAME			
PE-150/13.8/0.208					General Assembly Drawing			
DRAWN	CHECKED	CHECKED		APPROVED	FIRST ANGLE PROJECTION	SCALE	1	
Mike	Jack	Iris		Sam	PE™ TRANSFORMER REV. NO. 0			

NOTE:

- 1.ALL DIMENSIONS ARE IN MILLIMETERS
- 2.MATERIAL:STAINLESS STEEL
- 3.THICKNESS :1mm
- 4.LETTER COLOR: BLACK



CHANGE		TYPE		DWG. NAME				
		PE-L-500/12.47/0.48		Name Plate				
		FIRST ANGLE PROJECTION	SCALE	1	DRAWN	CHECKED	CHECKED	APPROVED
		2024-10-20		2	Mike		Jack	Iris
					REF. DWG. NO.			REV. NO.
					DWG. NO.	8PE.860.2483		0