









ITEM	WEIGHT(LBS)
CORE WEIGHT	2135 LBS
TOTAL OIL WEIGHT	1690 LBS
TOTAL WEIGHT	5740 LBS

TECHNICAL DATA	
RATING	500kVA
PRIMARY VOLTAGE(V)	12470Grdy/7200V
SECONDARY VOLTAGE(V)	208Grdy/120
FREQUENCY	60Hz
VECTOR GROUP	YNyn0
CONDUCTOR	ALUMINUM
PRIMARY BIL VOLTAGE	MINERAL OIL
SECONDARY BIL VOLTAGE	95kV
INSULATING OIL	30kV
TEMPERATURE RISE	65°C
EFFICIENCY	99.35%
IMPEDANCE	4.0-6.0%
ALTITUDE	≤1000m
COLOR	MUBSELL NO.7.0 GY 3.2/1.5
CORE FORM	THREE-PHASE THREE-COLUMN



PARTS LIST		
ITEM	DESCRIPTION	QTY
1	HV BUSHING (TG2-25/200)WITH 200AMP BUSHING WELL INSERTS	6
2	PARKING STAND BRACKET	5
3	DRIP TRAY	3
4	BAYONET FUSE(4000353C14M)	3
5	OIL LEVEL GAUGE(UH2-01)	1
6	FILL PLUG	1
7	PRESSURE RELIEF VALVE	1
8	VACUUM PRESSURE GAUGE(YZ-70)	1
9	OIL TEMPERATURE GAUGE(BWS-70)	1
10	NAMEPLATE	1
11	DOOR HANDLE	1
12	LV BUSHING(FTG1-1/1600,6 HOLE,BIL:30kV)	4
13	GROUND STEEL PADS	4
14	1"DRAIN VALVE WITH 3/8" SAMPLER	1
15	FLIP TOP COVER	1
16	LIFTING LUG	4
17	ELSP FUSE(CBUC08150D100)	3
18	TAP CHANGER(WSLII3 63/20-6x5)	1
19	BUSHING SPADE SUPPORT	4
20	CONNECTED STEEL-PLATE	4



500/12.47/0.208

DWG. NAME

General Assembly Drawing

DRAWN	CHECKED	CHECKED	APPROVED
Mike	Jack	Iris	Sam

FIRST ANGLE PROJECTION	SCALE	1
---------------------------	-------	---


JZP
SINCE 1989 FROM USA

REV.
NO.



ZGS500-231116-01

TOP VIEW OF BASE & HV-LV COMPARTMENT




CHANGE	</									
--------	--	--	--	--	--	--	--	--	--	--

ZGS500-231116-01

NOTE:

- 1.ALL DIMENSIONS ARE IN MILLIMETERS
- 2.MATERIAL:STAINLESS STEEL
- 3.THICKNESS :1mm
- 4.LETTER COLOR: BLACK



3 PHASE DISTRIBUTION
PAD MOUNTED TRANSFORMER

PRODUCT NO. :

TYPE ZGSL-H-500/12.47

CONDUCTOR MATERIAL: ALUMINIUM

PHASE 3

FREQUENCY 60Hz

TEMPERATURE RISE 65°C/65°C

EFFICIENCY 99.35%

DATE OF MFG.: 2023-11

NO PCB


CORE & COIL (UNTANKING) : 2135

TANK & FITTINGS:


LIQUID: 225 GALS

TOTAL:

RATED VOLTAGE	SWITCH POSITION	RATED CURRENT
13094	1	22.05
12782	2	22.58
12470	3	23.15
12158	4	23.74
11847	5	24.37



H. V. Um/BIL/AC 15/95/0 kV
L. V. Um/BIL/AC 1.5/30/10 kV



www.jiezoupower.com



CHANGE		TYPE		DWG. NAME	
		ZGSL-H-500/12.47/0.48		Name Plate	
		FIRST ANGLE PROJECTION		DRAWN	
		SCALE 1/2		CHECKED	
				CHECKED	
				APPROVED	
		MikeJlack Iris		SAM	
		REF. DWG. NO.		REV. NO.	
		DWG. NO.			
		ZGS500-231116-01			

