



Algal Engineering Ltd.

515 Consumers Rd, Suite 100
Toronto, Ontario, M2J 4Z2
Tel: (416) 484-0707 Fax: (416) 849-0148
E-mail: algal@algal.ca

Shop Drawings Review Report

Document Number: AE-21193-SDRR-E02		Revision: R00	Date: 2024-03-05
To: Gojko ROGLIC			
Project Name: OPG PNG Feeders F2 Upgrades			
Project Address: 1 BROCK ROAD, PICKERING, ONTARIO			
Client Project Number: NA			
Algal Project Number: AE-21019			
Client Name: OPG-PICKERING			
Client Address: 1 BROCK ROAD, PICKERING, ONTARIO			
Drawings Received on: 2024-02-29			
We have reviewed following shop drawings, with corresponding remarks:			
Item description:	Manufacturer:	Remarks:	
Transformer T21, 1500kVA, 4,16kV, 347/600V, 3ph, Oil filled, (Cu)	JZP	As submitted	
Comments:			
The shop drawings have been reviewed and approved with no comments.			
Reviewed by:			
Titu Mititelu	Project Manager		2024-03-05
Name	Title	Signature	Date



ITEM	WEIGHT(LBS)
CORE WEIGHT	3960 LBS
TOTAL OIL WEIGHT	2350 LBS
TOTAL WEIGHT	8725 LBS


TECHNICAL DATA	
RATING	1500kVA ✓
PRIMARY VOLTAGE(V)	4160 DELTA
SECONDARY VOLTAGE(V)	600GrdY/346
FREQUENCY	60Hz ✓
VECTOR GROUP	Dyn1
CONDUCTOR	COPPER
PRIMARY BIL VOLTAGE	60kV ✓
SECONDARY BIL VOLTAGE	30kV ✓
INSULATING OIL	MINERAL OIL ✓
TEMPERATURE RISE	65°C
LOAD LOSS AT RATED VOLTAGE	12500W
NO LOAD LOSSES	1200W
IMPEDANCE	5.75%
ALTITUDE	≤1000m
COLOR	MUBSELL NO.7.0 GY 3.2/1.5
CORE FORM	THREE-PHASE THREE-COLUMN

PARTS LIST		
ITEM	DESCRIPTION	QTY
1	HV BUSHING (15kV,300A)	6
2	PARKING STAND BRACKET	6
3	TAP CHANGER(WSLII3 63/20-6×5)	1
4	LIFTING LUG	4
5	NAMEPLATE	1
6	PENTAHEAD BOLT ARRANGEMENT	3
7	FILL PLUG	1
8	LIQUID LEVEL INDICATOR	1
9	PRESSURE RELIEF DEVICE(YSF9-35/25SKJ)	1
10	VACUUM PRESSURE GAUGE	1
11	THERMOMETER(BWPK-802A-2)	1
12	LV BUSHING(FTG1-1/2000,10 HOLE,BIL;30kV)	4
13	FLIP TOP COVER	1
14	HINGED DOOR	2
15	TERMINAL BLOCK	1
16	GROUND TERMINAL	1
17	GROUND STRAP COPPER	1
18	1"DRAIN VALVE WITH 3/8" SAMPLER	1
19	DOOR HANDLE	1
20	CEA GROUND BRACKET	1
21	BUSHING SPADE SUPPORT	4




TYPE					DWG. NAME				
ZGS-H-1500/4.16/0.6					General Assembly Drawing				
DRAWN	CHECKED	CHECKED		APPROVED	FIRST ANGLE PROJECTION	SCALE	1		
Mike	Jack	Iris		Sam	JZP SINCE 1989 FROM USA				REV. NO.
ZGS1500-240227-01									
									△ 0

NOTE:

- 1.ALL DIMENSIONS ARE IN MILLIMETERS
- 2.MATERIAL:STAINLESS STEEL
- 3.THICKNESS :1mm
- 4.LETTER COLOR: BLACK



CHANGE											
TYPE				DWG. NAME							
ZGS-H-1500/4.16/0.6				Name Plate							
FIRST ANGLE PROJECTION		SCALE		1 / 2		DRAWN		CHECKED	CHECKED		APPROVED
2024-02-27				Mike Jack		Iris				Sam	
				REF. DWG. NO.						REV. NO.	
				DWG. NO.		ZGS1500-240227-01					

PRESSURE RELIEF DEVICE
PRDOIL LEVEL INDICATOR
OLIOIL TEMPERATURE INDICATOR
OTI

X1:Terminal Block		
Label	NO.	Function
PRD-2	1	alarm
PRD-3	2	
PRD-1	3	
	4	
PRD-5	5	
PRD-6	6	
PRD-4	7	
	8	
OLI-D1	9	
OLI-D2	10	
OLI-D3	11	
OTI-2	9	
OTI-3	10	
OTI-1	11	
		Spare
	25	

Q'TY	NO	NAME	MATERIAL	DWG NO.	CODE	SIZE	U. WEIGHT	G. WEIGHT	REMARK
1	1	PRD	3×1.5mm ² ZR-KVVP ₂			5 m			
1	2	OLI	3×1.5mm ² ZR-KVVP ₂			3m			
1	3	OTI	3×1.5mm ² ZR-KVVP ₂			3m			

TYPE 1500KVA,4.16/0.6kV				DWG. NAME Secondary wiring diagram					
DRAWN	CHECKED	CHECKED		APPROVED	FIRST ANGLE PROJECTION	SCALE	1		
Mike	Jack	Iris		Sam	REF. DWG. NO.				REV. NO.
JZP SINCE 1999 FROM CHINA					DWG. NO.	ZGS1500-240227-01			1