







UNIT: MM



L.V. TERMINAL



WIRING DIAGRAM



TECHNICAL DATA

|                            |                                      |
|----------------------------|--------------------------------------|
| RATING                     | 500kVA                               |
| PRIMARY VOLTAGE            | 12470/7200V                          |
| SECONDARY VOLTAGE          | 600/347V                             |
| FREQUENCY                  | 60Hz                                 |
| VECTOR GROUP               | Yyn0                                 |
| WINDING MATERIAL           | LV.AL HV.CU                          |
| LOAD LOSS AT RATED VOLTAGE | 5410W                                |
| NO LOAD LOSSES             | 600W                                 |
| IMPEDANCE                  | 5.75%                                |
| ALTITUDE                   | ≤1000m                               |
| No. OF TAP POSITION        | 5                                    |
| COLOR                      | SEAFOAM GREEN MUNSELL 4.82G4.07/3.35 |
| CORE FORM                  | THREE-PHASE FIVE-COLUMN              |

| ITEM               | WEIGHT |
|--------------------|--------|
| TANK & ACCESSORIES | 870Kg  |
| TOTAL OIL WEIGHT   | 1000L  |
| TOTAL WEIGHT       | 2750Kg |

| ITEM | DESCRIPTION                              | QTY. |
|------|------------------------------------------|------|
| 1    | HV BUSHING, 15kv, 200A, 95kv BIL         | 3    |
| 2    | PARKING STAND                            | 3    |
| 3    | 2-POSITION LOAD BREAK SWITCH             | 1    |
| 4    | TAP CHANGER                              | 1    |
| 5    | BAYONET DRIP TRAY                        | 1    |
| 6    | OIL FILL PLUG                            | 1    |
| 7    | BAYONET FUSE HOLDER                      | 3    |
| 8    | PENTAHEAD BOLTS WITH FLOATING NUT        | 2    |
| 9    | NAMEPLATE SS                             | 1    |
| 10   | OIL LEVEL GAUGE                          | 1    |
| 11   | PRESSURE RELIEF VALVE                    | 1    |
| 12   | VACUUM PRESSURE GAUGE                    | 1    |
| 13   | OIL THERMOMETER GAUGE                    | 1    |
| 14   | PADLOCK DOOR AND LOCK C/W PENTAHEAD BOLT | 1    |
| 15   | LV BUSHING 4 HOLE                        | 4    |
| 16   | COPPER GROUND BAR, 40mm                  | 1    |
| 17   | 1" DRAIN/SAMPLING VALVE                  | 1    |
| 18   | ELSP CLF CBUC15150D100 (150A)            | 3    |
| 19   | LIFTING LUG                              | 4    |
| 20   | FLIP TOP COVER                           | 1    |
| 21   | RAIN COVER                               | 1    |
| 22   | HINGED DOOR                              | 2    |
| 23   | FOUNDATION TIE DOWN CLAMP                | 2    |
| 24   | BAYONET FUSES 4000358C12                 | 3    |

|      |              |     |      |                                             |
|------|--------------|-----|------|---------------------------------------------|
| 4    | 08/15/2023   | WG  | JHL  | UPDATED LIFTING LUGS AS PER CLIENT COMMENTS |
| 3    | 08/11/2023   | WG  | JHL  | UPDATED BOM AS PER CLIENT COMMENTS          |
| 2    | 07/27/2023   | WG  | JHL  | UPDATED AS PER CLIENT COMMENTS              |
| 1    | 07/07/2023   | WG  | JHL  | UPDATED DIMENSION UNIT FROM INCH TO MM      |
| 0    | 07/06/2023   | WG  | JHL  | ISSUED FOR REVIEW                           |
| REV. | (MM/DD/YYYY) | DSN | APPD | DESCRIPTION                                 |



|                                                                  |                                                           |
|------------------------------------------------------------------|-----------------------------------------------------------|
| ZGS-Z-500-12.47                                                  | CITY OF PENTICTON                                         |
| CHECKED: [Signature] DESIGNED: [Signature] APPROVED: [Signature] | SCALE 1/16 2023/07/06                                     |
| P.O. # 107064                                                    | DWG. TITLE 500kVA Pad-mounted Transformer Outline Drawing |
| DRAWING NUMBER 3JZP.710.30928J                                   | REV. 4                                                    |