

| PARTS LIST |                                 |     |
|------------|---------------------------------|-----|
| ITEM       | DESCRIPTION                     | QTY |
| 1          | HV BUSHING (15kv,200A)          | 2   |
| 2          | PARKING STAND BRACKET           | 1   |
| 3          | NON                             | N   |
| 4          | BAY-O-NET FUSE                  | 1   |
| 5          | FUSE HOLDER                     | 1   |
| 6          | TAP CHANGER 1PH                 | 1   |
| 7          | OIL LEVEL GAUGE                 | 1   |
| 8          | 1" UPPER FILL VALVE             | 1   |
| 9          | PRESSURE RELIEF VALVE           | 1   |
| 10         | LIFTING LUG                     | 4   |
| 11         | LV BUSHING(1.2kv 5/8 )          | 3   |
| 12         | 4 HOLE SPAD                     | 3   |
| 13         | NAMEPLATE                       | 1   |
| 14         | GROUND STEEL PADS (TTC2)        | 4   |
| 15         | FIXED PROJECTING CUP            | 1   |
| 16         | PADLOCK                         | 1   |
| 17         | 1"DRAIN VALVE WITH 3/8" SAMPLER | 1   |
| 18         | CURRENT LIMITING FUSE           | 2   |
| 19         | TANK                            | 1   |
| 20         | COVER                           | 1   |
| 21         | BOLT FOR LIFTING                | 1   |
| 22         | HOLD-DOWN PLATE                 | 4   |
| 23         | CUPPED WASHER                   | 4   |
| 24         | GROUND PAD                      | 2   |
| 25         | EQUIPOTENTIAL DEVICE(COPPER)    | 1   |

PADMOUNT TYPE

ONAN 60HZ,65°C

|                                |     |    |             |                       |                      |
|--------------------------------|-----|----|-------------|-----------------------|----------------------|
| SINGLE                         | PH. | 15 | kVA         | SERIAL NO.            |                      |
| IMPEDANCE AT 85°C              |     |    | %           | VOL OF OIL            | L                    |
| BIL                            |     |    | 95/30       | kV                    | TOTAL MASS           |
| HV.                            |     |    | 7200±2×2.5% | V                     | MAT HV.&LV.          |
| LV.                            |     |    | 120/240     | V                     | POLARITY             |
|                                |     |    |             |                       | POLARITY IS ADDITIVE |
| BAYONET FUSE                   |     |    | 4000353C08B | CURRENT LIMITING FUSE | CBUC15030C100        |
| ENERGY EFFICIENCY PER DOE 2016 |     |    |             |                       | < 1PPM PCB           |
| CURRENT LIMITING FUSE          |     |    |             |                       | APPLIED STANDARD     |
|                                |     |    |             |                       | IEEE.C57.12.29       |
|                                |     |    |             |                       | PRODUCTION PLACE     |
|                                |     |    |             |                       | CHINA                |
|                                |     |    |             |                       | DATE OF MFG.         |

WWW.JIEZOUPOWER.COM

|             |         |                |           |            |  |      |
|-------------|---------|----------------|-----------|------------|--|------|
|             |         |                |           |            |  | DWG: |
|             |         |                |           |            |  |      |
|             |         |                |           |            |  |      |
|             |         |                |           |            |  |      |
| REMARK      | SUBAREA | ALTERATION NO. | SIGNATION | DATE       |  |      |
| DESIGN      |         |                | VERIFY    |            |  |      |
| CHECK       |         |                | APPROVE   | JY         |  |      |
| CRAFT       |         |                |           |            |  |      |
| STANDARDIZE |         |                | DATE      | 12/04/2024 |  |      |

Nameplate



JIEZOU POWER

A/0