

DETAIL

M10



PARTS LIST		
ITEM	DESCRIPTION	QTY
1	Core&Coil Assemble	1
2	Tank Cover	1
3	Pressure Relief Device	1
4	Grounding Terminal	3
5	Tap Changer	1
6	Mark	1
7	Nameplate	1
8	LV Bushing	2
9	Lifting Hook	2
10	HV Bushing	1
11	Lightning Arrester Nut	4
12	Electrical Connection Of The Cover To The Tank	1
13	Copper Strip	1
14	Tank	1
15	Transformer Oil	

					DL-100/24.94/0.347 Outling Drawing			
Remart	Time	Subarea	Signature	Date		JIE ZOU POWER		
Design	XBW	Standardiza						
Date	03/22/24							TRANSFORMER
Check	JACK	Verify	IRIS					
Craft		Approve	SAM					



SINGLE PHASE POLE
MOUNTED TRANSFORMER

1 PH 100 kVA SERIAL NO.

IMPEDANCE AT 85°C % PRODUCT NO.


BIL 125/30 kV TEMPRATURE RISE 65°C

HV 24940GRDY/144400 V CONDUCTOR MATERIAL AL

LV 347/600Y V FREQUENCY 60Hz

☐ POLARITY ADDITIVE TYPE OF OIL MINERAL ☐


STANDARD PER CSA C 2.2 < 1PPM PCB



VOL OF OIL:

TOTAL MASS:

DATE OF MFG.



JIEZOU POWER

www.jiezoupower.com