




TECHNICAL DATA	
RATING	75kVA
PRIMARY VOLTAGE(V)	22860/13200
SECONDARY VOLTAGE(V)	120-240
INSULATION LEVEL(kV) H.V BIL	125
INSULATION LEVEL(kV) L.V BIL	30
FREQUENCY	60Hz
VECTOR GROUP	II0
CONDUCTOR	AL
INSULATING OIL	MINERAL OIL PCB
TEMPERATURE RISE	65°C
LOAD LOSS AT RATED VOLTAGE	850W
NO LOAD LOSSES	130W
IMPEDANCE	1.8%
ALTITUDE	≤1000m
COLOR	Munsell Green 7GY 3.29/1.5

ITEM	WEIGHT
UNTANK WEIGHT	512 Lbs
TOTAL OIL WEIGHT	617 Lbs
TOTAL WEIGHT	1653 Lbs


PARTS LIST		
ITEM	DESCRIPTION	QTY
1	LV BUSHING	3
2	TANK	1
3	Bayonet Fuse	1
4	FUSE HOLDER	1
5	Drip Shield Assembly	1
6	Oil	
7	Backup Fuse	1
8	Fuse Assembly	1
9	Bolt	1
10	Washer	1
11	Core & Coil Assembly	1
12	PRESSURE RELIEF VALVE	1
13	OIL LEVEL GAUGE	1
14	Oil-in Plug	1
15	Nameplate	1
16	HV Bushing Base and terminal	2
17	Earth Terminal	1
18	Oil drain valve(Oil sampling valve)	1
19	BOIT FOR EARTH	1
20	COPPER STRIP	1
21	Bolt for lifting	4
22	Cover	1




S.NO	JZP.1PD.00075.13200	DESCRIPTION	
		JZP-75/13.2-0.12(0.24)	
		Pad-Mounted Transformer	
Remark	Time	Signature	Date
Design	Mike	Standardize	Jack
Date	2023.10.14	Verify	Iris
Check		Approve	Sam
Craft		Date	2023.10.14
		Total	No.



JIEZOU POWER



Connection Diagram



TECHNICAL DATA

RATING	100kVA
PRIMARY VOLTAGE(V)	22860/13200
SECONDARY VOLTAGE(V)	120-140
INSULATION LEVEL(KV) H.V.BIL	125
INSULATION LEVEL(KV) L.V.BIL	30
FREQUENCY	60Hz
VECTOR GROUP	LI0
CONDUCTOR	AL
INSULATING OIL	MINERAL NO PCB
TEMPERATURE RISE	65°C
LOAD LOSS AT RATED VOLTAGE	1150W
NO LOAD LOSSES	150W
IMPEDANCE	1.8%
ALTITUDE	≤1000m
COLOR	Munsell Green 7C/ 3.29/1.5

ITEM	WEIGHT
UNTANK WEIGHT	705 Lbs
TOTAL OIL WEIGHT	654 Lbs
TOTAL WEIGHT	1841 Lbs

PARTS LIST

ITEM	DESCRIPTION	QTY
1	LV BUSHING	3
2	TANK	1
3	Bayonet Fuse	1
4	FUSE HOLDER	1
5	Drip Shield Assembly	1
6	Oil	
7	Backup Fuse	1
8	Fuse Assembly	1
9	Bolt	1
10	Washer	1
11	Core & Coil Assembly	1
12	PRESSURE RELIEF VALVE	1
13	OIL LEVEL GAUGE	1
14	Oil-in Plug	1
15	Nameplate	1
16	HV Bushing Base and terminal	2
17	Earth Terminal	1
18	Oil drain valve(Oil sampling valve)	1
19	BOIT FOR EARTH	1
20	COPPER STRIP	1
21	Bolt for lifting	4
22	Cover	1



S.NO JZP.1PD.00100.13200 DESCRIPTION

JZP-100/13.2-0.12(0.24)

Pad-Mounted Transformer

Remark	Time	Subarea	Alteration No.	Signature	Date
Design	Mike	Standardize		Jack	
Date	2023.10.14	Verify		Iris	
Check		Approve		Sam	
Craft		Date	2023.10.14		

Phase Remark	Weight	Scale
A/O		
Total		No.



JIEZOU POWER

