




JIEZOU POWER

SUBSTATION TRANSFORMER

STANDARDS IEEE. C57. 12. 00
1500kVA HV 13200V DELTA
LV 550V Grdy/318

TYPE OF COLING ONAN/ONAF
PERCENT IMPEDANCE: 5. 65 %
TYPE OF OIL 45# NO PCB
CORE & COLL (UNTAKING): LBS
TANK & FITTINGS: LBS
LIQUID: GALS LBS
TOTAL: LBS




VECTOR GRAPH (Dyn1)


H. V WIRING

L. V WIRING

SCHEMATIC DIAGRAM



SCHEMATIC DIAGRAM



PRODUCT NO. : 1SLT. 711. XXXXXX
TYPE SF-1300/1500/13. 2/0. 55
CONDUCTOR MATERIAL: ALUMINUM
PHASE 3
FREQUENCY 60Hz
TEMPERATURE RISE 65° C/ 65° C
SERIAL NO. :
DATE OF MFG. :
H. V. Um/BIL/AC 15/95/34 kV
L. V. Um/BIL/AC 0. 55/30/10 kV

Tapping Range		H. V			L. V		
		Voltage (V)	Current (A)		Voltage (V)	Current (A)	
			ONAN	ONAF		ONAN	ONAF
1	+5 %	13860	54. 15	62. 48	550	1364. 65	1574. 59
2	+2. 5 %	13530	55. 47	64. 01			
3	Rated	13200	56. 86	65. 61			
4	-2. 5 %	12870	58. 32	67. 29			
5	-5 %	12540	59. 85	69. 06			

DE-ENERGIZE TRANSFORMER
BEFORE OPERATING TAPCHANGER

ITEM:
MANUFACTURER:
PART NUMBER:

WWW. JIEZOUPOER. COM

160
175