

Bar Bending Schedule (BBS) Report

Generated on 05-May-2026 07:44 | Element: **Slab** | Standards: IS 456:2000, IS 2502:1963

1. Input Parameters

Parameter	Value	Parameter	Value
Element	Slab	Cover (mm)	20
Shorter Span (mm)	3500	Longer Span (mm)	5000
Main Bar Dia (mm)	10	Main Bar Spacing (mm)	150
Dist. Bar Dia (mm)	8	Dist. Bar Spacing (mm)	200
Hook Type	135°	Lap Length (mm)	0

2. Bar Bending Schedule

Bar Mark	Element	Description	Dia (mm)	Shape	Cutting Len (mm)	Qty	Total Len (m)	Unit Wt (kg/m)	Total Wt (kg)
M1	Slab	Main Bar (along shorter span)	10.0	Straight w/ hooks	3660.0	35	128.1	0.617	79.07
D1	Slab	Distribution Bar (along longer span)	8.0	Straight	4960.0	19	94.24	0.395	37.23
TOTAL							222.34		116.3

3. Final Steel Order (with 5% wastage, 12 m rods)

Dia (mm)	Net Length (m)	Net Weight (kg)	Wastage %	Order Length (m)	Order Weight (kg)	12 m Rods
8.0	94.24	37.23	5%	98.95	39.09	9
10.0	128.1	79.07	5%	134.5	83.02	12
GRAND TOTAL				233.45	122.11	

✓ **Engineering Verified** — Independent recalculation of total_length & weight per row passed.

This report is auto-generated. Verify against site drawings before fabrication. Hook lengths and bend deductions follow IS 2502.