SITE SAFETY INSPECTION CHECKLIST

Regular safety walkthrough — complete weekly or as required

Project: _____ Inspector: _____ Date: _____

GENERAL SITE CONDITIONS

	Item	Status
☐	Site fencing and hoarding secure and in good condition	
☐	Site signage displayed (builder details, safety signs)	
☐	Access and egress routes clear and unobstructed	
☐	Housekeeping — site tidy, materials stored safely	
☐	Waste managed — skip bins not overflowing, sorted correctly	
☐	Amenities clean and functional (toilet, hand wash, lunch area)	

PERSONAL PROTECTIVE EQUIPMENT

	Item	Status
☐	All workers wearing hard hats in required areas	
☐	High-visibility clothing worn by all personnel	
☐	Safety footwear (steel cap boots) worn by all	
☐	Eye protection available and used where required	
☐	Hearing protection available near noisy work	
☐	Gloves and other task-specific PPE available	

FALL PREVENTION

	Item	Status
☐	Edge protection installed on open edges > 2m	
☐	Scaffolding erected by competent person, tagged current	
☐	Scaffold boards secure, no gaps, kickboards installed	
☐	Ladders in good condition, secured at top	
☐	Penetrations and openings covered or barricaded	
☐	Safety mesh / catch platforms installed (if required)	

ELECTRICAL SAFETY

	Item	Status
☐	RCDs (safety switches) installed and tested	
☐	All leads and tools tested and tagged (current)	

	Item	Status
☐	No damaged leads, plugs, or connections	
☐	Temporary power board in good condition	
☐	Overhead power line exclusion zones maintained	

EXCAVATION & EARTHWORKS

	Item	Status
☐	Excavations benched, battered, or shored (if > 1.5m)	
☐	Barriers around open excavations	
☐	Services located and marked (DBYD)	
☐	Soil stockpiles stable and clear of edge	

FIRE PREVENTION

	Item	Status
☐	Fire extinguisher on site, serviced and accessible	
☐	Hot work permits in place (welding, cutting, grinding)	
☐	Flammable materials stored safely	
☐	No smoking in prohibited areas	

EMERGENCY PREPAREDNESS

	Item	Status
☐	First aid kit stocked and accessible	
☐	Emergency contact list displayed	
☐	Emergency evacuation plan and assembly point known	
☐	Trained first aider on site	

ACTIONS REQUIRED:

1. _____ Due: _____

2. _____ Due: _____

3. _____ Due: _____

4. _____ Due: _____

5. _____ Due: _____

Inspector: _____ Signature: _____ Date: _____