Site safety inspection

Weekly site safety walk-through: site conditions, PPE, fall prevention, electrical, excavation, fire and emergency preparedness.

Project		Date	
Completed by		Signature	

Walk the site with this list at least weekly, and after any change in conditions (new high-risk work, after storms). Fix or isolate anything unsafe before work continues, record the inspection in the site diary, and raise recurring issues at the next toolbox talk. See work health and safety.

General Site Conditions

Item	Done	Notes
Site fencing and hoarding secure and in good condition	☐	
Site signage displayed (builder details, safety signs)	☐	
Access and egress routes clear and unobstructed	☐	
Housekeeping — site tidy, materials stored safely	☐	
Waste managed — skip bins not overflowing, sorted correctly	☐	
Amenities clean and functional (toilet, hand wash, lunch area)	☐	

Personal Protective Equipment

Item	Done	Notes
All workers wearing hard hats in required areas	☐	
High-visibility clothing worn by all personnel	☐	
Safety footwear (steel cap boots) worn by all	☐	
Eye protection available and used where required	☐	
Hearing protection available near noisy work	☐	
Gloves and other task-specific PPE available	☐	

Fall Prevention

Item	Done	Notes
Edge protection installed on open edges > 2m	☐	
Scaffolding erected by competent person, tagged current	☐	
Scaffold boards secure, no gaps, kickboards installed	☐	
Ladders in good condition, secured at top	☐	
Penetrations and openings covered or barricaded	☐	
Safety mesh / catch platforms installed (if required)	☐	

Electrical Safety

Item	Done	Notes
RCDs (safety switches) installed and tested	☐	
All leads and tools tested and tagged (current)	☐	
No damaged leads, plugs, or connections	☐	
Temporary power board in good condition	☐	
Overhead power line exclusion zones maintained	☐	

Excavation & Earthworks

Item	Done	Notes
Excavations benched, battered, or shored (if > 1.5m)	☐	
Barriers around open excavations	☐	
Services located and marked (Before You Dig Australia, BYDA)	☐	
Soil stockpiles stable and clear of edge	☐	

Fire Prevention

Item	Done	Notes
Fire extinguisher on site, serviced and accessible	☐	
Hot work permits in place (welding, cutting, grinding)	☐	
Flammable materials stored safely	☐	
No smoking in prohibited areas	☐	

Emergency Preparedness

Item	Done	Notes
First aid kit stocked and accessible	☐	
Emergency contact list displayed	☐	
Emergency evacuation plan and assembly point known	☐	
Trained first aider on site	☐	