



TEST REPORT

Report No:	EFEL/PRO/2026/01/872	Issue Date	27/01/2026
Name and Address of Customer	M/s. Powergid Corporation of India Limited 765/400KV Padghe GIS Substation Vashind - Ambadi Road, Village: Khaniwaali Taluka: Bhiwandi Dist: Thane-421604 State: Maharashtra		
Sample Name	Drinking Water	Sample Description	Drinking Water
Date of Sampling	21/01/2026	Sampling duration	--
Start Date of Analysis	22/01/2026	End Date of Analysis	27/01/2026
Sampling Location	--	Sampling Procedure	APHA 1060
Sampling done by	M/s. One Stop Safety Services	Sample Quantity	1 Ltr

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (IS 10500)	Methods
1	pH at 25°C	7.12	--	6.5 to 8.5	APHA 4500 H+ A, 23rd Ed.2017
2	Color	Colorless	5	Hazen	IS : 3025 (Part 4):1983
3	Odour	Unobjectionable	Agreeable	--	IS : 3025 (Part 5):1983
4	Taste	Agreeable	Agreeable	--	IS : 3025 (Part 7 and 8):1984
5	Turbidity	<1.1	NTU	--	IS : 3025 (Part 10):1984
6	Electrical Conductivity	<3	µS/cm	<5	IS : 3025 (Part 14):1984
7	Total Dissolved Solids TDS	51.2	mg/lit	<500	APHA 2540 C, 23rd Ed.2017
8	Total Hardness (as CaCO ₃)	40.3	mg/lit	<200	IS 3025 (Part 21)
9	Total Alkalinity	24.0	mg/lit	<200	IS 3025 (Part 23)
10	Sulphate (as SO ₄)	14.1	mg/lit	<200	IS 3025 (Part 24)
11	Nitrate (as NO ₃)	0.5	mg/lit	<45	APHA 4500 NO ₃ , 23rd Ed.2017
12	Fluoride (as F)	<0.05	mg/lit	<1.0	APHA 4500 F, 23rd Ed.2017
13	Residual Free Chlorine	<0.05	mg/lit	<0.2	APHA 4500 Cl, 23rd Ed.2017
14	Chloride (as Cl)	12.7	mg/lit	<250	APHA 4500 Cl-, 23rd Ed.2017
15	Calcium (as Ca)	13.2	mg/lit	<75	IS 3025 (Part 40)
16	Magnesium (as Mg)	3.4	mg/L	<30	IS 3025 (Part 46)
17	Phenolic compound	<0.001	mg/lit	<0.001	IS:3025(Part 43)
18	Mineral oil	<0.1	mg/lit	<0.5	IS3025(part 39):1991
19	Nitrite	<0.1	mg/lit	--	IS3025(part 34):1988
20	Iron (as Fe)	<0.04	mg/lit	<0.3	APHA 3111, 23rd Ed.2017
21	Copper as Cu	<0.01	mg/lit	<0.05	APHA 3111, 23rd Ed.2017
22	Mercury as Hg	<0.001	mg/lit	<0.001	APHA 3111, 23rd Ed.2017
23	Cadmium as Cd	<0.001	mg/lit	<0.003	APHA 3111, 23rd Ed.2017
24	Selenium as Se	<0.01	mg/lit	<0.01	APHA 3111, 23rd Ed.2017
25	Arsenic as As	<0.01	mg/lit	<0.01	APHA 3111, 23rd Ed.2017

Laboratory Accredited by NABL

Laboratory Recognized by Ministry of Environment, Forest (MoEF) & Climate Change (CC) Govt. of India.

Registered Address: Flat No. A-5, Balaji palace, Kharadi Road,
Chandan Nagar, Tal. Haveli, Dist. Pune - 411014.

Certifications: ISO 9001 : 2015
• ISO 14001: 2015 • ISO 45001 : 2018



26	Lead as Pb	<0.01	mg/lit	<0.01	APHA 3111, 23 rd Ed.2017
27	Zinc as Zn	<0.1	mg/lit	<5	APHA 3111, 23 rd Ed.2017
28	Hexavalent Cr	<0.01	mg/lit	<0.05	APHA 3111, 23 rd Ed.2017
29	Aluminum as Al	<0.01	mg/lit	<0.03	APHA 3111, 23 rd Ed.2017
30	Boron as B	<0.1	mg/lit	<1.0	APHA 3111, 23 rd Ed.2017
31	Total Coliform	Absent	MPN/100ml	<2	IS 1622:1981
32	E.coli.	Absent	MPN/100ml	<2	IS 1622:1981
33	Faecal coliforms	Absent	Per 100ml	--	IS 1622-1981

Remark-

- The above water sample is Comply with required limit as per 10500:2012.
- For Total Coliform & *E.coli*. <2 can be consider as Zero [Refer IS:1622 (R.A.1996), Table No.-4].



Authorized Signatory
Mr. Mahesh Shelar
(Managing Director)
Page 01 of 01

Laboratory Accredited by NABL

Laboratory Recognized by Ministry of Environment, Forest (MoEF) & Climate Change (CC) Govt. of India.

📍 **Registered Address:** Flat No. A-5, Balaji palace, Kharadi Road,
Chandan Nagar, Tal. Haveli, Dist. Pune - 411014.

Certifications: ISO 9001 : 2015
• ISO 14001: 2015 • ISO 45001 : 2018