


NOTES:

1. RATINGS ARE PRELIMINARY AND SUBJECT TO CHANGE DURING DETAILED DESIGN.
2. AUXILIARY TRANSFORMER KIOSKS OPERATE IN RADIAL CONFIGURATION UNDER NORMAL OPERATING CONDITIONS, BUT HAVE THE CAPABILITY TO OPERATE AS A RING UNDER FAULT OR MAINTENANCE CONDITIONS.



[illegible]

This drawing and the related information have been prepared by, or at the request of, Beyond Electrical Engineering (BEE) for a specific purpose and may not be used for any purpose other than the purpose intended by BEE. BEE does not provide any warranties and accepts no liability arising out of the use of this drawing or any of the related information for any purpose other than the intended purpose. This drawing is protected by copyright and no part of this drawing may be reproduced in any form without the express written permission of BEE.



HEYWOOD BESS
33kV RETICULATION
SINGLE LINE DIAGRAM
33 kV SWITCHBOARDS No.1 & 2

NOT FOR CONSTRUCTION

Drawing Status <i>CONCEPT</i>				
Drawing N° 250479-ELE-SLD-0003				
Size A1	Scale NTS			Rev N° B