
COX

Research and Technology, Inc.

TRIPLEX PUMP
CONTROL PANEL
PLAQUEMINE

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2284

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	3	
HP	15	
FLA	42 (est)	
TYPE OF PUMP	Self Priming	(Self-Priming, Submersible)
MANUFACTURER		
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 3R	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Stainless Steel	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR		(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X (pilot only)	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X (3)	
NEMA RATED STARTERS	X	
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		

SOLD TO: Delta Process - New Orleans, LA
TAG : PLAQUEMINE

SHIP TO: Delta Process - Denham Springs, LA

	Drawing Title							
	PANEL DESCRIPTION							
DATE 2/03/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY CTR	ECN	DATE	BY
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
	TRIPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2284	
							SHEET NUMBER 1	



	Drawing Title								
	POWER DIAGRAM								
DATE 2/03/06		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED		
	Project Title				BY	CTR	BY	DATE	
	TRIPLEX PUMP CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER		
							DRAWING NUMBER CP-2284		
							SHEET NUMBER 2		

COX

Research and Technology, Inc.


P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030

PURCHASE ORDER NUMBER

DRAWING NUMBER
CP-2284

SHEET NUMBER



Drawing Title

CONTROL DIAGRAM

DATE
2/03/06


Project Title

TRIPLEX PUMP
CONTROL PANEL


REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED		
			BY	CTR	BY	DATE	
<div>COX</div> <div>Research and Technology, Inc.</div>					PURCHASE ORDER NUMBER		
					DRAWING NUMBER CP-2284		
					SHEET NUMBER 3		

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030



	Drawing Title							
	CONTROL DIAGRAM							
DATE 2/03/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY CTR	DATE BY	DATE DATE	BY DATE
	Project Title	<div> <div>COX</div> <div>Research and Technology, Inc.</div> </div>			<div> <div>P.O. Box 77808</div> <div>Baton Rouge, LA 70809</div> <div>Ph. (225)756-3271</div> <div>Fax (225)755-1030</div> </div>		PURCHASE ORDER NUMBER	
	TRIPLEX PUMP CONTROL PANEL						DRAWING NUMBER CP-2284	
							SHEET NUMBER 4	



NAMEPLATE SCHEDULE

NP-1	PUMP 1	NP-10	O.L. RESET
NP-2	PUMP 2	NP-11	O.L. RESET
NP-3	PUMP 3	NP-12	O.L. RESET
NP-4	HOA	NP-13	HIGH TEMP RESET
NP-5	HOA	NP-14	HIGH LEVEL
NP-6	HOA	NP-15	LOW LEVEL
NP-7	HIGH TEMP		
NP-8	HIGH TEMP		
NP-9	HIGH TEMP		


Drawing Title									
ENCLOSURE									
DATE	2/03/06	REFERENCE DRAWING	S/N	NO.	Sales Engineer	Application Engineer	REVISION-LOCATION	ECN	DATE
		C.C.		R.C.			BY CTR	BY	DATE
Project Title						PURCHASE ORDER NUMBER			
TRIPLEX PUMP CONTROL PANEL						DRAWING NUMBER			
						CP-2284			
						SHEET NUMBER			

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030



NAMEPLATE SCHEDULE

NP-1 PUMP 1/RUN
NP-2 PUMP 2/RUN
NP-3 PUMP 3/RUN

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

	Drawing Title
--	---

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	C & I	C-363010SRHPL	3R S.S. ENCLOSURE
1a	1	C & I	CI-36P30	BACK PLATE
1b	1	C & I	CI-3630SPA	DEAD FRONT
2	1	BUSSMANN	16371-3	DISTRIBUTION BLOCK
3	3	SQUARE D	QOU380	CB 1,2,3
4	3	ABB	A50N2-30-11-84	MS 1,2,3
5	3	ABB	TA75DU52	O.L. 1,2,3 (36-52A)
6	1	DIVERSIFIED	ARM-120-ACE	TRIPLEX ALTERNATOR
7	3	SSAC	PLMU-11	PHASE MONITOR
8	1	DELTA	LA603	LIGHTNING ARRESTOR
9	1	IDEC	RU4SA110V	CR1
10	3	A-B	800H-JR2A	HOA
11	5	A-B	800H-QR10R	PILOT LIGHT-RED
12	1	A-B	800H-AR2A	PUSH BUTTON
13	3	ABB	KPR3-104BMR	O.L. RESET P.B.
14	3	REDINGTON	711-0190	ELAPSED TIME METER
15	3	MAGNECRAFT	W388AMLCPX-9	CR3,4,5
16	2	IDEC	RY2S-UAC-120V	CR5,6
17	3	A-B	800H-QR10A	AMBER PILOT LIGHTS
18	1	IDEC	RU4SA110V	CR1
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				

	Drawing Title								
	BILL OF MATERIALS								
DATE 2/03/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY		
	Project Title				DRAWN BY CTR		APPROVED BY DATE		
	TRIPLEX PUMP CONTROL PANEL	<div><div></div><div>COX</div><div>Research and Technology, Inc.</div><div></div></div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER		
DRAWING NUMBER CP-2284									
SHEET NUMBER 7									