



FUSE SELECTION CHART

| MOTOR FULL LOAD CURRENT | TYPICAL TIME DELAY FUSE SIZE REQUIRED | CRT PART NO. |
|-------------------------|---------------------------------------|--------------|
| 1-4 AMPS | 5 AMPS | AE845-4180 |
| 4-8 AMPS | 10 AMPS | AE845-4184 |
| 8-12 AMPS | 15 AMPS | AE845-4187 |
| 12-16 AMPS | 20 AMPS | AE845-4188 |

* FUSE SIZE VARIES WITH COMPRESSOR SIZE PER NATIONAL ELECTRIC CODE

NOTE

- INTERNAL MOTOR THERMAL OVERLOAD IS RECOMMENDED.

LEGEND

| | |
|------|--------------------|
| — | WIRING BY VENDOR |
| ---- | WIRING BY CUSTOMER |



Delta Environmental Products, Inc.
P.O. Box 969 Denham Springs, LA 70727

SCHEMATIC DIAGRAM NUTRI-CLEAR™ CONTROL PANEL

DWN BY:
C. RACHAL

DATE:
9/29/04

SCALE:
N.T.S.

DWG. NO.:
CP-1899

JOB NO.: