
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
PEARL RIVER
5HP

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2108

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	5	
FLA	28.5	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	HYDROMATIC	
CATALOG NUMBER	G2HX500CD	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	YES	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS	X	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER	X	
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		


SOLD TO: Delta Process - New Orleans, LA
TAG : Pearl River

SHIP TO: Delta Process - Denham Springs, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 7/12/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL						DRAWING NUMBER CP-2108
							SHEET NUMBER 1



	Drawing Title								
	POWER DIAGRAM								
DATE 7/12/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	APPROVED
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2108			
						SHEET NUMBER 2			



Drawing Title							
CONTROL DIAGRAM							
DATE 7/12/05		REFERENCE DRAWING		NO.		REVISION-LOCATION	
Project Title		S/N		Sales Engineer C.C.		Application Engineer R.C.	
DUPLIX PUMP CONTROL PANEL				BY C. RACHAL		APPROVED	
						BY	
						DATE	
						PURCHASE ORDER NUMBER	
						DRAWING NUMBER	
						CP-2108	
						SHEET NUMBER	
						3	

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030



NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030

PURCHASE ORDER NUMBER	
-----------------------	--

DRAWING NUMBER	CP-2108
----------------	---------

SHEET NUMBER

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	ALLIED	AM2420RLDF	ENCLOSURE
1a	1	ALLIED	BP2420AL	BACKPLATE
2	1	ABB	OT100E3	MAIN DISC. SWITCH
3	2	ABB	A30-30-10-84	MOTOR STARTER
4	2	ABB	TA25DU32	O.L. (24-32A)
5	2	SQUARE D	QOU260	CB1, CB2
6	2	SQUARE D	QOU115	CB3
7	1	TIMEMARK	261DT120	ALTERNATING RELAY
8	4	ACI	JR22FR	RED PILOT LIGHT
9	2	ACI	JR22P3M20B	HOA SWITCH
10	1	AC/DC	BL5-R-120	ALARM LIGHT
11	1	MARATHON	1323580	DISTRIBUTION BLOCK
12	2	REDINGTON	711-0190	ELAPSED TIME METER
13	2	SSAC	LLC54AA	SEAL FAIL RELAY
14	1	DELTA	LA302	LIGHTNING ARRESTER
15	1	STOCK		GFI
16	2			μf START CAPACITOR
17	2			μf RUN CAPACITOR
18	2			START RELAY
19	1	SSAC	FS126RC	FLASHER
20	2	DAYTON	2A561	TIME DELAY
21				
22				
23				
24				
25				

	Drawing Title						
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>						
DATE 7/12/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 100px;"> <h1 style="margin: 0;">COX</h1> </div> <p style="margin: 0;">Research and Technology, Inc.</p>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER <div style="text-align: right;">CP-2108</div> SHEET NUMBER <div style="text-align: right;">5</div>
	DUPLEX PUMP CONTROL PANEL						