



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

**NOTE:**  
SEWER GASES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASES.

	Drawing Title						
	ENCLOSURE						
DATE 07/23/14	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION DRAWN Application Engineer R.C.	ECN	DATE	BY	
	Project Title						
	DUPLEX PUMP CONTROL PANEL						
	COX						
	Research and Technology, Inc.						
	P.O. Box 77808 Baton Rouge, LA 70809						
	Ph. (225)756-3271 Fax (225)755-1030						
	PURCHASE ORDER NUMBER						
	DRAWING NUMBER CP-2054						
	SHEET NUMBER						
	4						