

---

---

# COX

Research and Technology, Inc.

---

---

DUPLEX SUBMERSIBLE PUMP  
CONTROL PANEL  
MADISON PARISH

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	2.7	
FLA	9.0	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS	_____	(Submersible Only)
SEAL FAIL RELAYS	_____	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	X	(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN	_____	
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD	_____	
LIGHT FLASHER	_____	
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	_____	
PHASE MONITOR	_____	
NEMA RATED STARTERS	_____	
GROUND FAULT RECPT.	_____	
GREEN RUN LIGHTS VS. RED	_____	
POLE, BOX, SEAL	_____	
INTRINSICALLY SAFE RELAYS	_____	
HIGH TEMP. LOCKOUT, MANUAL RESET	_____	
ECONOMY VERSION	_____	
HEATER	_____	


SOLD TO: Delta Process - Ruston, LA  
 TAG : MADISON PARISH

SHIP TO: Delta Process - Ruston, LA


Drawing Title	PANEL DESCRIPTION							
	REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
DATE 3/06/06	S/N	Sales Engineer	Application Engineer	DRAWN	APPROVED			
		C.C.	R.C.	BY C. RACHAL	BY	DATE		
Project Title								
DUPLEX PUMP CONTROL PANEL		COX		P.O. Box 77808 Baton Rouge, LA 70809				
		Research and Technology, Inc.		Ph. (225)756-3271 Fax (225)755-1030				
					DRAWING NUMBER	CP-2330		
					SHEET NUMBER	1		



	Drawing Title					
	POWER DIAGRAM					
DATE 3/06/06	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY
Project Title CONTROL PANEL	<b>COX</b> Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2330 SHEET NUMBER 2	



	Drawing Title  CONTROL DIAGRAM				
		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL
DATE 3/06/06				APPROVED BY	DATE BY
	Project Title  CONTROL PANEL	<hr/> <hr/> <b>COX</b> <hr/> <hr/> Research and Technology, Inc.	<hr/> <hr/> <hr/>	P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER  DRAWING NUMBER CP-2330 SHEET NUMBER 3
				Ph. (225)756-3271 Fax (225)755-1030	





#### NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

**NOTE:**  
SEWER GASES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASES.

DATE 3/06/06	Drawing Title  <b>ENCLOSURE</b>								
		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE BY	
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED		
			C.C.	R.C.	BY C. RACHAL		BY	DATE	
Project Title  <b>CONTROL PANEL</b>		<hr/> <b>COX</b> <hr/> Research and Technology, Inc. <hr/>				P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER		
							DRAWING NUMBER CP-2330		
							SHEET NUMBER 4		



FS1 – FLOAT SWITCH 1  
 ALL PUMPS OFF  
 FS2 – FLOAT SWITCH 2  
 LEAD PUMP ON  
 FS3 – FLOAT SWITCH 3  
 LAG PUMP ON  
 FS4 – FLOAT SWITCH 4  
 HIGH LEVEL ALARM  
 TS1/MD1 – TEMP. SWITCH/MOISTURE DETECTOR 1  
 TS2/MD2 – TEMP. SWITCH/MOISTURE DETECTOR 2

	Drawing Title				
	EXTERNAL CONNECTIONS				
DATE 3/06/06	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY DATE
Project Title CONTROL PANEL	<b>COX</b> Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER  DRAWING NUMBER CP-2330 SHEET NUMBER 5

## BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	2	ABB	A16-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU11	O.L. RELAY (7.5-11A)
4	2	SQUARE D	QOU320	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	2	ACI	JR22P3M20B	HOA SWITCH
7	2	ACI	JR22FR	RED LIGHT
8	1	AC/DC	BL5-R-120	ALARM LIGHT
9	1	MARATHON	1323580	DISTRIBUTION BLOCK
10	1	MARATHON	1321580	NEUTRAL BLOCK
11	1	DELTA	LA603	LIGHTNING ARRESTER
12	1	SQUARE D	QOU110	CB3
13	1	ABB	OT63E3	MAIN DISCONNECT
14				
15				

Drawing Title  <b>BILL OF MATERIALS</b>							
	REFERENCE DRAWING		NO.	REVISION-LOCATION	ECN	DATE	BY
DATE 3/06/06	S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE 6	
Project Title  <b>CONTROL PANEL</b>	<hr/> <hr/> <b>COX</b> <hr/> <hr/> Research and Technology, Inc. <hr/> <hr/>				P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER	
						DRAWING NUMBER CP-2330	
						SHEET NUMBER 6	