

---

---

# COX

Research and Technology, Inc.

---

---

DUPLEX PUMP  
CONTROL PANEL  
LAKE BISTINEAU

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

CP-2366

VOLTAGE	<u>120/240V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>1/60</u>	
NO. MOTORS	<u>2</u>	
HP	<u>2</u>	
FLA	<u>15</u>	
TYPE OF PUMP	<u>Submersible</u>	(Self-Priming, Submersible)
MANUFACTURER	<u>BARNES</u>	
CATALOG NUMBER	<u>SGVF2022L-MS</u>	
CONTROL VOLTAGE	<u>120V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 4X</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Fiberglass</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u>Floats</u>	(Floats, Bubbler, Other)
CAPACITORS	<u>YES</u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u>N/A</u>	
THERM. & SEAL FAIL WIRING FIGURE	<u> </u>	

OPTIONS:

SEAL FAIL LIGHTS	<u>X</u>	(Submersible Only)
SEAL FAIL RELAYS	<u> </u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u> </u>	(Submersible Only)
HT PUMP SHUTDOWN	<u> </u>	(Self-Primer, Submersible)
ALARM HORN	<u> </u>	
ALARM LIGHT	<u>X</u>	
LIGHT PANEL MTD	<u>X</u>	
LIGHT REMOTE MTD	<u> </u>	
LIGHT FLASHER	<u> </u>	
LIGHTNING ARRESTER	<u>X</u>	
ELAPSED TIME METER	<u>X</u>	
PHASE MONITOR	<u> </u>	
NEMA RATED STARTERS	<u> </u>	
GROUND FAULT RECPT.	<u> </u>	
GREEN RUN LIGHTS VS. RED	<u> </u>	
POLE, BOX, SEAL	<u> </u>	
INTRINSICALLY SAFE RELAYS	<u> </u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u> </u>	
ECONOMY VERSION	<u> </u>	

SOLD TO: Delta Process - Bossier City, LA


TAG : LAKE BISTINEAU


 

SHIP TO: Delta Process - Ruston, LA


 

	Drawing Title						
	PANEL DESCRIPTION						
DATE 4/20/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title  DUPLIX PUMP CONTROL PANEL	<div style="text-align: center;">   Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
					Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2366
							SHEET NUMBER 1



	Drawing Title								
	POWER DIAGRAM								
DATE 4/20/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	APPROVED
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2366			
						SHEET NUMBER 2			




	Drawing Title    CONTROL DIAGRAM							
DATE 4/20/06			REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN BY	DATE DATE
	Project Title  DUPLEX PUMP CONTROL PANEL		COX  Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER CP-2366  SHEET NUMBER 3

**COX**

Research and Technology, Inc.

P.O. Box 77808  
Baton Rouge, LA  
70809

Ph. (225)756-3271  
Fax (225)755-1030



VIEW OF SWING OUT PANEL

**NOTE:**  
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

	Drawing Title  ENCLOSURE								
DATE 4/20/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	
	Project Title  DUPLEX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER		
							DRAWING NUMBER CP-2366		
							SHEET NUMBER		
							4		

## BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	1	DELTA	LA302R	LIGHTNING ARRESTER
3	2	ABB	A16-30-10-84	MOTOR STARTER
4	2	ABB	TA25DU19	O.L. (13-19A)
5	2	SQUARE D	QOU230	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	4	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	AC/DC	BL5-R-120	ALARM LIGHT
10	1	MARATHON	1323580	DISTRIBUTION BLOCK
11	2	REDINGTON	711-0190	ELAPSED TIME METER
12	1	SQUARE D	QOU110	CB3
13	2	MALLORY	4CU54	143 $\mu$ f CAPACITOR
14	2	DAYTON	2GU20	45 $\mu$ f CAPACITOR
15	2	GE	6X559	START RELAY
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 4/20/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> <b>COX</b>  Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030		APPROVED BY C. RACHAL DATE 
	DUPLIX PUMP CONTROL PANEL				PURCHASE ORDER NUMBER  DRAWING NUMBER CP-2366 SHEET NUMBER 5		