
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
HARBOR CENTER S.T.P. GOV

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2176

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	5	
FLA	25	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	Hydromatic	
CATALOG NUMBER		

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	Yes	(Yes, No)
CAPACITOR WIRING FIGURE		
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:


SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN	X (INGRAM)	
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER		
ELAPSED TIME METER		
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL	X	
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		

SOLD TO: Delta Process - Denham Springs, LA


TAG : HARBOR CENTER S.T.P. GOV

SHIP TO: Delta Process - Ruston, LA


	Drawing Title						
	PANEL DESCRIPTION						
DATE 10/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLIX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2176
							SHEET NUMBER 1



	Drawing Title								
	POWER DIAGRAM								
DATE 10/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2176			
						SHEET NUMBER 2			



Drawing Title							
CONTROL DIAGRAM							
DATE	10/11/05	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
Project Title		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL		APPROVED BY DATE
DUPLEX PUMP CONTROL PANEL		COX			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
		Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2176
							SHEET NUMBER 3



VIEW OF SWING OUT PANEL

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL
NP-9	SILENCE

	Drawing Title ENCLOSURE							
DATE 10/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
	Project Title DUPLUX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER		
						DRAWING NUMBER CP-2176		
						SHEET NUMBER		
						4		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HWPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
	1	MARATHON	1323580	DIST. BLOCK
2	2	ABB	A26-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU25	O.L. RELAY (18-25A)
4	2	SQUARE D	QOU245	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	4	ACI	JR22FR	RED PILOT LIGHT
7	2	ACI	JR22P3M20B	HOA SWITCH
8	1	AC/DC	BL5-R-120	ALARM LIGHT
9	1	ACI	JR22AN11B	PUSH BUTTON
10	1	ABB	OT100E3	DISCONNECT SWITCH
11	1	INGRAM	PW120AB	ALARM
12	1	INGRAM	SM120A	SILENCE MODULE
13	2	FRANKLIN ELECTRIC	279322122	RUN CAP 60 μ f @370V
14	2	FRANKLIN ELECTRIC	275468118	START CAP 216-259 μ f @330V
15	2	FRANKLIN ELECTRIC	155031102	START RELAY
16	2	ABB	LLC54AA	SEAL FAIL RELAY
17	1	IDEC	RH1BUAC110	CR1
18				
19				
20				
21				
22				
23				
24				

	Drawing Title						
	BILL OF MATERIALS						
DATE 10/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 100px;"> COX <small>Research and Technology, Inc.</small> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER <div style="text-align: right;">CP-2176</div> SHEET NUMBER <div style="text-align: right;">5</div>
	DUPLEX PUMP CONTROL PANEL						