
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
TOWN OF STERLINGTON

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2220

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	15	
FLA	<42	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	Gorman Rupp	
CATALOG NUMBER		

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Float Switches	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE		
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET	X	
ECONOMY VERSION		


SOLD TO: Delta Process Equipment, Inc. - Ruston, LA
TAG : Town of Sterlington

SHIP TO: Delta Process Equipment, Inc. - Ruston, LA


	Drawing Title						
	PANEL DESCRIPTION						
DATE 12/08/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLIX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2220
							SHEET NUMBER 1



	Drawing Title							
	POWER DIAGRAM							
DATE 12/08/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE	BY
	Project Title	COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-2220		
						SHEET NUMBER 2		



Drawing Title									
CONTROL DIAGRAM									
DATE 12/08/05	REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE	BY
	S/N		Sales Engineer C.C.		Application Engineer R.C.		DRAWN BY C. RACHAL		APPROVED BY DATE
Project Title								PURCHASE ORDER NUMBER	
DUPLEX PUMP CONTROL PANEL								DRAWING NUMBER CP-2220	
								SHEET NUMBER 3	



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	HIGH TEMP RESET

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

Drawing Title	ENCLOSURE		REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE	BY
DATE			S/N		Sales Engineer		Application Engineer		DRAWN		APPROVED
12/08/05			C.C.		R.C.		BY C. RACHAL		BY		DATE
Project Title			COX		P.O. Box 77808 Baton Rouge, LA 70809		Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER		
DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.								DRAWING NUMBER CP-2220		
									SHEET NUMBER		4

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	2	ABB	A40-30-10-84	MOTOR STARTER
3	2	ABB	TA42DU42	O.L. RELAY (29-42A)
4	2	SQUARE D	QOU380	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	2	ACI	JR22FR	RED PILOT LIGHT
7	2	ACI	JR22P3M20B	HOA SWITCH
8	2	ACI	JR22FY	AMBER PILOT LIGHT
9	1	ACI	JR22AN11B	PUSH BUTTON
10	1	DELTA	LA603	LIGHTNING ARRESTER
11	2	REDINGTON	711-0190	ELAPSED TIME METER
12	2	MAGNECRAFT	W388AMLCPX-9	LATCHING RELAY CR1,2
13	1	SQUARE D	QOU110	CB3
14	1	AC/DC	BL5-R-120	ALARM LIGHT
15	1	MARATHON	1323580	DISTRIBUTION BLOCK
16	1	MARATHON	1321580	NEUTRAL BLOCK
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>						
DATE 12/08/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> <h1 style="margin: 0;">COX</h1> <p style="margin: 0;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER <div style="text-align: right;">CP-2220</div> SHEET NUMBER
	<h2 style="margin: 0;">DUPLEX PUMP CONTROL PANEL</h2>	5					