

COX

Research and Technology, Inc.

PUMP & COMPRESSOR CONTROL PANEL


Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030




VIEW OF FRONT OF ENCLOSURE

	Drawing Title							
	ENCLOSURE		1	NOTE JUMPER/REDUNDANT OFF FLOAT		5/12/06		
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
8/6/09		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY J.HEUGHAN	BY	DATE	
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	PUMP & COMPRESSOR CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2056A/D		
						SHEET NUMBER 2		

CP2056A CONTROL PANEL



VIEW OF INTERIOR OF ENCLOSURE



* REMOVE BAR JUMPER IF REDUNDANT OFF FLOAT IS REQUIRED

	Drawing Title				
	ENCLOSURE	1	NOTE JUMPER/REDUNDANT OFF FLOAT	5/12/06	
DATE 8/7/09		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN DATE BY
	Project Title	S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY J.HEUGHAN APPROVED BY DATE
	PUMP & COMPRESSOR CONTROL PANEL	<div data-bbox="792 1955 911 2001">COX</div> <div data-bbox="729 2009 971 2034">Research and Technology, Inc.</div>		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2056A/D SHEET NUMBER 3

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	J1210HAPL	ENCLOSURE
1a	1	STAHLIN	BP1210AL	BACKPLATE
2	2	SQUARE D	QOU120	CB1,2
3	1	SIEMENS	LOGO! OBA5	PLC
4	1	ABB	A16-30-10-84	CONTACTOR
5	2	ACI	MONOBLOCK	PILOT LIGHT
6	2	ACI	JR22AN20B	PUSH BUTTON
7	1	HERGA	SINGLE	PRESSURE SWITCH
8	1	U.S. CONTROL	10191-60	BUZZER
9	9	WEIDMUELLER	WDU4	TERMINAL BLOCK
10	2	WEIDMUELLER	WSI6	FUSE HOLDER
11	3	WEIDMUELLER	WDU6	TERMINAL BLOCK
12	1	ABB	ISVR430120R0100	TIME DELAY RELAY
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title							
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>							
			1	NOTE JUMPER/REDUNDANT OFF FLOAT			5/12/06	
DATE 8/7/09		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY J.HEUGHAN	ECN	DATE	BY
		APPROVED		BY		DATE		
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 150px;"> <h3 style="margin: 0;">COX</h3> <p style="margin: 0; font-size: small;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		<div style="border: 1px solid black; padding: 2px; margin: 0;">PURCHASE ORDER NUMBER</div> <div style="border: 1px solid black; padding: 2px; margin: 0;">DRAWING NUMBER CP-2056A/D</div> <div style="border: 1px solid black; padding: 2px; margin: 0;">SHEET NUMBER 4</div>	

RECOMMENDED SPARE PARTS

ITEM	QTY	MANUFACTURER	DESCRIPTION
1	1	ABB	TIME DELAY RELAY
2	1	COX	BULB
3	1	SIEMENS	PLC
4	1	ABB	CONTACTOR
5	2	ACI	PUSH BUTTON
6	1	COX	PRESSURE SWITCH
7	1	COX	BUZZER
8			
9			
10			

	Drawing Title							
	Spare Parts							
			1	NOTE JUMPER/REDUNDANT OFF FLOAT			5/12/06	
DATE 8/7/09		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY J.HEUGHAN		APPROVED BY DATE	
		<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2056A/D SHEET NUMBER 5		
	Project Title							
	PUMP & COMPRESSOR CONTROL PANEL							

PARAMETERS

(FACTORY SETTINGS)



PARAMETER SETTINGS ARE REQUIRED IN RCT MODE ONLY.

FROM THE FOLLOWING SCREEN

ON	XX:XX	← ON TIME
OFF	XX:XX	← OFF TIME
	XX:XX	← TIME REMAINING

PRESS FOR 2 SECONDS

PRESS

TOGGLE SETTINGS WITH C3   C4 AND
PRESS
PRESS

