





Delta Environmental Products, Inc.

ECOPOD
COMPRESSOR
CONTROL PANEL



FS1 - HL, FLOAT SWITCH, (OPTIONAL.)
* FUSE SIZE VARIES WITH COMPRESSOR SIZE
PER NATIONAL ELECTRIC CODE.
- A SEPARATE DISCONNECT IS REQUIRED.



SETTING HIGH LEVEL PRESSURE SWITCH
BRING PLANT TO OPERATING WATER LEVEL WITH COMPRESSOR TURNED ON.
USING PROPERLY SIZED SCREW DRIVER, TURN HIGH LEVEL ALARM ADJUSTMENT
SCREW CLOCKWISE UNTIL ALARM OCCURS, THEN TURN THE SCREW COUNTER-CLOCKWISE
UNTIL ALARM STOPS.

BRING PLANT TO OPERATING WATER LEVEL WITH COMPRESSOR TURNED ON. USING PROPERLY SIZED SCREW DRIVER, TURN HIGH LEVEL ALARM ADJUSTMENT SCREW CLOCKWISE UNTIL ALARM OCCURS, THEN TURN THE SCREW COUNTER-CLOCKWISE UNTIL ALARM STOPS.

