

ENVIRONMENTAL CONSTRUCTION CORP.

CWS, DIV.

JAMAICA
DUPLEX BLOWER
CONTROL PANEL

Environmental Construction Corp.
P.O. Box 396
Pass Christian, MS 39571
(228) 255-5353 Fax (228) 255-6095

CP-1866

VOLTAGE	<u>440V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>3/50</u>	
NO. MOTORS	<u>2</u>	
HP	<u>3</u>	
FLA	<u>3.9A</u>	
TYPE OF PUMP	<u>Blower</u>	(Self-Priming, Submersible)
MANUFACTURER	<u></u>	
CATALOG NUMBER	<u></u>	
CONTROL VOLTAGE	<u>110V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 4X</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Fiberglass</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u></u>	(Floats, Bubbler, Other)
CAPACITORS	<u></u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u></u>	
THERM. & SEAL FAIL WIRING FIGURE	<u></u>	

OPTIONS:


SEAL FAIL LIGHTS	<u></u>	(Submersible Only)
SEAL FAIL RELAYS	<u></u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u></u>	(Submersible Only)
HT PUMP SHUTDOWN	<u></u>	(Self-Primer, Submersible)
ALARM HORN	<u></u>	
ALARM LIGHT	<u></u>	
LIGHT PANEL MTD	<u></u>	
LIGHT REMOTE MTD	<u></u>	
LIGHT FLASHER	<u></u>	
LIGHTNING ARRESTER	<u></u>	
ELAPSED TIME METER	<u></u>	
PHASE MONITOR	<u></u>	
NEMA RATED STARTERS	<u></u>	
GROUND FAULT RECPT.	<u></u>	
GREEN RUN LIGHTS VS. RED	<u></u>	
POLE, BOX, SEAL	<u></u>	
INTRINSICALLY SAFE RELAYS	<u></u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u></u>	
ECONOMY VERSION	<u></u>	

SOLD TO: Environmental Construction Corp.


TAG : Jamaica Blower Control Panel

SHIP TO:

	Drawing Title						
	PANEL DESCRIPTION						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
8/09/04		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	Environmental Construction Corp. P.O. Box 396 Pass Christian, MS 39571 (228) 255-5353 Fax (228) 255-6095				PURCHASE ORDER NUMBER	
	DUPLEX BLOWER CONTROL PANEL					DRAWING NUMBER CP-1866	
						SHEET NUMBER 1	



	Drawing Title							
	POWER DIAGRAM							
DATE	8/09/4	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE	
	Project Title	Environmental Construction Corp.				PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL	P.O. Box 396 Pass Christian, MS 39571 (228) 255-5353 Fax (228) 255-6095				DRAWING NUMBER CP-1866		
						SHEET NUMBER 2		




PANEL IS DESIGNED TO RUN AERATORS WITH A MINIMUM OF 15 MINUTES OF OFF TIME BETWEEN ALTERNATION. PINS PUSHED OUT ON CLOCK INDICATE RUN TIME. PINS PUSHED IN INDICATE OFF TIME. EACH PIN IS EQUAL TO 15 MINUTES.

IF NO OFF TIME IS REQUIRED BETWEEN ALTERNATION, REMOVE JUMPER FROM TERMINALS ⑤ AND ⑥ PLACE JUMPER ACROSS TERMINALS ⑦ AND ⑧ NOW AERATORS WILL RUN CONTINUOUSLY. SET 1 PIN IN AT THE TIME YOU WISH THE AERATORS TO ALTERNATE. ALL REMAINING PINS SHOULD BE PUSHED OUT.

* REMOVE JUMPERS AND INSTALL LOCKOUT DEVICES IF REQUIRED

	Drawing Title CONTROL DIAGRAM							
DATE 8/09/04			REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN
	S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL		APPROVED BY DATE		
	Project Title DUPLEX BLOWER CONTROL PANEL		Environmental Construction Corp. P.O. Box 396 Pass Christian, MS 39571 (228) 255-5353 Fax (228) 255-6095				PURCHASE ORDER NUMBER	
DRAWING NUMBER CP-1866								
SHEET NUMBER 3								

Environmental Construction Corp.
P.O. Box 396
Pass Christian, MS 39571
(228) 255-5353 Fax (228) 255-6095



VIEW OF FRONT COVER

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	BLOWER 1
NP-2	BLOWER 2
NP-3	HOA
NP-4	HOA

	Drawing Title							
	ENCLOSURE							
DATE 8/09/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE	BY
	Project Title	Environmental Construction Corp. P.O. Box 396 Pass Christian, MS 39571 (228) 255-5353 Fax (228) 255-6095				PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL					DRAWING NUMBER CP-1866		
						SHEET NUMBER 4		

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	VYNCKIER	VJ1816HPL	ENCLOSURE
2	1	VYNCKIER	MP1816A	BACKPLATE
3	2	ABB	A16-30-10-84	STARTER
4	2	ABB	TA25DU5.0	O.L. 1,2 (3.5-5.0A)
5	2	ABB	S1N015TL	CIRCUIT BREAKER 1,2
6	1	ABB	OT63E3	DISCONNECT SWITCH
7	1	DIVERSIFIED	ARB-120-ADA	ALTERNATING RELAY
8	1	GRASSLIN	FM/1 QRTUZH	TIMER
9	2	ACI	JR22P3M20B	H.O.A. SWITCH
10	1	ABB	T4150PSF-1	TRANSFORMER
11	1	MARATHON	1323580	DISTRIBUTION BLOCK
12				
13				
14				
15				

	Drawing Title							
	BILL OF MATERIALS							
DATE 8/09/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
						APPROVED BY	DATE	
	Project Title	Environmental Construction Corp. P.O. Box 396 Pass Christian, MS 39571 (228) 255-5353 Fax (228) 255-6095				PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL					DRAWING NUMBER CP-1866		
						SHEET NUMBER 5		