
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
MAGNOLIA CHASE SUBDIVISION

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030


CP-1689


CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION	X	


SHIP TO: Delta Process - Shreveport, LA

	Drawing Title							
	PANEL DESCRIPTION							
DATE 8/06/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY	
	Project Title					PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	COX Research and Technology, Inc.				P.O. Box 77808 Baton Rouge, LA 70809		
						Ph. (225)756-3271 Fax (225)756-1030		
						DRAWING NUMBER CP-1689		
						SHEET NUMBER 1		





Drawing Title							
CONTROL DIAGRAM							
DATE 8/06/03	REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN
	S/N		Sales Engineer C.C.		Application Engineer R.C.		DATE
Project Title		BY C. RACHAL		APPROVED		BY	DATE
DUPLEX PUMP CONTROL PANEL		PURCHASE ORDER NUMBER		DRAWING NUMBER CP-1689		SHEET NUMBER	3
		COX Research and Technology, Inc.		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030			



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NP-1 PUMP 1
NP-2 PUMP 2
NP-3 RUN
NP-4 RUN
NP-5 HOA
NP-6 HOA
NP-7 SEAL FAIL
NP-8 SEAL FAIL

	Drawing Title ENCLOSURE								
DATE 8/06/03			REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE
	S/N	Sales Engineer C.C.	Application Engineer R.C.		DRAWN BY C. RACHAL		APPROVED BY DATE		
	Project Title DUPLEX PUMP CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER	
DRAWING NUMBER									
SHEET NUMBER									
4									

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	VYNCKIER	VJ1816HWPLDF	ENCLOSURE
1a	1	VYNCKIER	MP1816AL	BACKPLATE
2	2	ABB	A16-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU11	O.L. RELAY (7.5-11A)
4	2	SQUARE D	QOU320	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	4	ACI	JR22FR	RED PILOT LIGHT
7	2	ACI	JR22P3M20B	HOA SWITCH
8	1	TOMAR	495-120R	ALARM LIGHT
9	1	C-H	CHSA03	LIGHTNING ARRESTER
10	1	SSAC	PLMU-11	PHASE MONITOR
11	2	GRASSLIN	UWZ52E	ELAPSED TIME METER
12	1	SQUARE D	QOU120	CB3
13	1	MARATHON	1323580	DISTRIBUTION BLOCK
14	1	HUBBELL	GFR5252GYA	GFI
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 8/06/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE BY
		<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 100px;"> COX <small>Research and Technology, Inc.</small> </div>		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER <div style="text-align: right;">CP-1689</div> SHEET NUMBER <div style="text-align: right;">5</div>	
	Project Title	DUPLEX PUMP CONTROL PANEL					