

---

---

COX

Research and Technology, Inc.

---

---

VILLAGE OF COLLINSTON  
DUPLEX PUMP  
CONTROL PANEL

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

CP-1804

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	7.5	
FLA	22	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN		(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER		
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION	X	

SOLD TO: Delta Process - Ruston, LA


TAG : VILLAGE OF COLLINSTON


\_\_\_\_\_

SHIP TO: Delta Process - Ruston, LA


\_\_\_\_\_

\_\_\_\_\_


	Drawing Title						
	PANEL DESCRIPTION						
DATE 5/17/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;">   <b>COX</b>  Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1804
							SHEET NUMBER 1



	Drawing Title							
	POWER DIAGRAM							
DATE 5/17/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE	BY
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1804		
						SHEET NUMBER 2		



Drawing Title	CONTROL DIAGRAM					
DATE 5/17/04	Project Title	<div> <div>COX</div> <div>Research and Technology, Inc.</div> </div>				<div> <div>P.O. Box 77808 Baton Rouge, LA 70809</div> <div>Ph. (225)756-3271 Fax (225)756-1030</div> </div>
		<div> <div>REFERENCE DRAWING</div> <div>NO.</div> <div>REVISION-LOCATION</div> </div>				<div> <div>ECN</div> <div>DATE</div> <div>BY</div> </div>
		<div> <div>S/N</div> <div>Sales Engineer C.C.</div> <div>Application Engineer R.C.</div> <div>DRAWN BY C. RACHAL</div> <div>APPROVED BY</div> </div>				<div> <div>PURCHASE ORDER NUMBER</div> <div>DRAWING NUMBER CP-1804</div> <div>SHEET NUMBER 3</div> </div>



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	HIGH TEMP RESET

**NOTE:**  
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASSES.

DATE 5/17/04	Drawing Title							
	ENCLOSURE							
REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE	BY
S/N		Sales Engineer C.C.		Application Engineer R.C.		DRAWN BY C. RACHAL		APPROVED BY
Project Title								DATE
DUPLEX PUMP CONTROL PANEL								PURCHASE ORDER NUMBER
								DRAWING NUMBER CP-1804
								SHEET NUMBER 4

**COX**

Research and Technology, Inc.

P.O. Box 77808  
Baton Rouge, LA  
70809

Ph. (225)756-3271  
Fax (225)756-1030

## BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	2	ABB	A26-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU25	O.L. RELAY (18-25A)
4	2	SQUARE D	QOU345	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	2	ACI	JR22FY	AMBER PILOT LIGHT
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	ACI	JR22AN11B	PUSH BUTTON
10	1	DELTA	LA603	LIGHTNING ARRESTER
11	2	MAGNECRAFT	W388AMLCPX-9	LATCHING RELAYS
12	1	AC/DC	BL5-R-120	ALARM LIGHT
13	1	SSAC	PLMU-11	PHASE MONITOR
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	<h3 style="margin: 0;">BILL OF MATERIALS</h3>						
DATE 5/17/04		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> <h2 style="margin: 0;">COX</h2> <p style="margin: 0;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER <div style="text-align: right;">CP-1804</div> SHEET NUMBER <div style="text-align: right;">5</div>
	DUPLEX PUMP CONTROL PANEL						