
COX

Research and Technology, Inc.

HANNAH'S PARK
OUASHITA PARISH
DUPLEX SUBMERSIBLE PUMP
CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-1735

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	6.2	
FLA	19.6	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 3R	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Painted Steel	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	X	(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS	X ABB	
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		
SWING INTERNAL DOOR	X	


SOLD TO: Delta Process - Ruston, LA
TAG : HANNAH'S PARK

SHIP TO: Delta Process - Ruston, LA


	Drawing Title						
	PANEL DESCRIPTION						
DATE 1/30/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	SUBMERSIBLE PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1735
					SHEET NUMBER 1		



	Drawing Title								
	POWER DIAGRAM								
DATE	1/30/04	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	APPROVED	
		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	BY	DATE		
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	SUBMERSIBLE PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1735			
						SHEET NUMBER 2			



	Drawing Title CONTROL DIAGRAM									
DATE 1/30/04			REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
			S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL		APPROVED BY DATE		
	Project Title SUBMERSIBLE PUMP CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1735 SHEET NUMBER 3		





VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

DATE 1/30/04	Drawing Title								
	ENCLOSURE								
	Project Title		SUBMERSIBLE PUMP CONTROL PANEL		COX Research and Technology, Inc.		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER
									DRAWING NUMBER CP-1735
									SHEET NUMBER 4



FS1 – FLOAT SWITCH 1
 ALL PUMPS OFF
 FS2 – FLOAT SWITCH 2
 LEAD PUMP ON
 FS3 – FLOAT SWITCH 3
 LAG PUMP ON
 FS4 – FLOAT SWITCH 4
 HIGH LEVEL ALARM
 TS1/MD1 – TEMP. SWITCH/MOISTURE DETECTOR 1
 TS2/MD2 – TEMP. SWITCH/MOISTURE DETECTOR 2

	Drawing Title							
	EXTERNAL CONNECTIONS							
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
1/30/04		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED		
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	SUBMERSIBLE PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1735		
						SHEET NUMBER 5		

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	EBE	24200REPL	ENCLOSURE
1a	1	EBE	A2420P	BACKPLATE
1b	1	EBE	A2420SP	DEAD FRONT
2	1	ABB	OT63E3	MAIN DISC. SWITCH
3	2	ABB	A26N1-30-10-84	MOTOR STARTER
4	2	ABB	TA25DU25	O.L. RELAY (18-25A)
5	2	SQUARE D	QOU340	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	SSAC	PLMU-11	PHASE MONITOR
10	1	AC/DC	BL5-R-120	ALARM LIGHT
11	1	DELTA	LA603	LIGHTNING ARRESTOR
12	2	GRASSLIN	UWZ52E	ETM
13	1	ABB	OHB65L5	HANDLE
14	1	ABB	EXP5X265	SHAFT
15	1	SQUARE D	QOU120	CB3
16	1	BELL	STOCK	GFI
17				
18				
19				
20				
21				
22				
23				
24				

	Drawing Title								
	BILL OF MATERIALS								
DATE 1/30/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	
	Project Title					PURCHASE ORDER NUMBER			
	SUBMERSIBLE PUMP CONTROL PANEL	COX Research and Technology, Inc.				P.O. Box 77808 Baton Rouge, LA 70809	DRAWING NUMBER CP-1735		
						Ph. (225)756-3271 Fax (225)756-1030	SHEET NUMBER		6