

FUSE SELECTION CHART


MOTOR FULL LOAD CURRENT	TYPICAL TIME DELAY FUSE SIZE REQUIRED	CRT PART NO.
1-4 AMPS	5 AMPS	AE845-4180
4-8 AMPS	10 AMPS	AE845-4184
8-12 AMPS	15 AMPS	AE845-4187
12-16 AMPS	20 AMPS	AE845-4188

NOTE

1. INTERNAL MOTOR THERMAL  
OVERLOAD IS RECOMMENDED.

LEGEND

—	WIRING BY VENDOR
----	WIRING BY CUSTOMER



Delta Environmental Products, Inc.  
P.O. Box 969 Denham Springs, LA 70727

# SCHEMATIC DIAGRAM NUTRI-CLEAR™ CONTROL PANEL

DWN BY:  
C.RACHAL

DATE:  
6/24/04

SCALE:  
N.T.S.

DWG. NO.:  
CP-1833

JOB NO.: