
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
SUGAR MILL PLANTATION
ADDIS, LA

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2127

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	40	
FLA	95.3	
TYPE OF PUMP	Self Priming	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER	T6A3S-B	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 3R	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Stainless Steel	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD		
LIGHT REMOTE MTD	X	
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		


SOLD TO: Delta Process - Denham Springs, LA
TAG : Sugar Mill Plantation
Addis, LA

SHIP TO: Delta Process - Ruston, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 8/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL						DRAWING NUMBER CP-2127
							SHEET NUMBER 1



	Drawing Title								
	POWER DIAGRAM								
DATE 8/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE	BY	APPROVED
	Project Title	<div> <div>COX</div> <div>Research and Technology, Inc.</div> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL						DRAWING NUMBER CP-2127		
							SHEET NUMBER 2		





Drawing Title							
CONTROL DIAGRAM							
DATE		REFERENCE DRAWING		NO.		REVISION-LOCATION	
8/11/05		S/N		Sales Engineer		Application Engineer	
Project Title		C.C.		R.C.		BY C. RACHAL	
DUPLIX PUMP CONTROL PANEL						APPROVED	
						BY	
						DATE	
						PURCHASE ORDER NUMBER	
						DRAWING NUMBER	
						CP-2127	
						SHEET NUMBER	
						3	

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	OVERLOAD RESET
NP-10	OVERLOAD RESET
NP-11	PUSH TO RESET

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

Drawing Title							
ENCLOSURE							
DATE 8/11/05		REFERENCE DRAWING		NO.		REVISION-LOCATION	
		S/N		Sales Engineer C.C.		Application Engineer R.C.	
Project Title				BY C. RACHAL		APPROVED	
DUPLIX PUMP CONTROL PANEL				P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2127	
						SHEET NUMBER 4	

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	EBE	S363010REPL	ENCLOSURE W/GASKET
1a	1	EBE	3630P	BACKPLATE
2	2	ABB	STOCK	O.L. RESET PUSH BUTTON
3	2	ABB	A145N4-30-11-84	MOTOR STARTER
4	2	ABB	TA200DU110	O.L. RELAY (80-110A)
5	2	ABB	S3N150TW	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	LUMAPRO	3RB24	REMOTE ALARM LIGHT
10	1	DELTA	LA603	LIGHTNING ARRESTER
11	1	SSAC	PLMU-11	PHASE MONITOR
12	2	REDINGTON	711-0190	ELAPSED TIME METER
13	1	ACI	JR22-AN11B	PUSH BUTTON
14	1	BUSSMAN	16332-3	DISTRIBUTION BLOCK
15	1	BUSSMAN	16332-1	NEUTRAL BLOCK
16	1	SAGINAW	SCE-TEMNC	THERMOSTAT
17	3	SQUARE D	QOU115	CB3,4,5
18	2	MAGNECRAFT	W388AMLCPX-9	LATCHING RELAYS
19	2	ACI	JR22FY	YELLOW PILOT LIGHT
20	1	STOCK		GFI RECEPTACLE
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 8/11/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2127 SHEET NUMBER 5
	DUPLEX PUMP CONTROL PANEL						