
COX

Research and Technology, Inc.

DUPLEX PUMP CONTROL PANEL RIVER HIGHLANDS

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	14	
FLA	36.0	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	GORMAN RUPP	
CATALOG NUMBER	JSV4E-14	
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	NO	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	X	(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER	X	
LIGHTNING ARRESTOR	X	
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		


SOLD TO: Delta Process - New Orleans, LA
TAG : River Highlands

SHIP TO: Delta Process - Denham Springs, LA


Drawing Title								
PANEL DESCRIPTION								
	REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
	S/N	Sales Engineer	Application Engineer	DRAWN	APPROVED			
		C.C.	R.C.	BY	C. RACHAL	BY	DATE	
Project Title							PURCHASE ORDER NUMBER	
DUPLEX PUMP CONTROL PANEL	COX				DRAWING NUMBER		CP-2138	
	Research and Technology, Inc.				SHEET NUMBER		1	



	Drawing Title					
	POWER DIAGRAM					
DATE 9/27/05	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY
Project Title						
DUPLEX PUMP CONTROL PANEL	COX	Research and Technology, Inc.	P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2138 SHEET NUMBER 2		



Drawing Title CONTROL DIAGRAM				
	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL
DATE 9/27/05				DATE APPROVED BY DATE
Project Title DUPLEX PUMP CONTROL PANEL	<hr/> <hr/> COX <hr/> <hr/> Research and Technology, Inc.		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2138 SHEET NUMBER 3



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

NOTE:
SEWER GASES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASES.

Drawing Title						
ENCLOSURE						
DATE 9/27/05	REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY DATE
Project Title DUPLEX PUMP CONTROL PANEL	<u>COX</u> Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2138 SHEET NUMBER 4	

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	ALLIED	AM24200RLDF	ENCLOSURE
1a	1	ALLIED	BP2420AL	BACKPLATE
2	1	ABB	OT1003E3	MAIN DISC. SWITCH
3	2	TELEMECHANIQUE	LC1D50G7	MOTOR STARTER
4	2	TELEMECHANIQUE	LRD3355	O.L. (30-40A)
5	2	SQUARE D	QOU370	CB1, CB2
6	1	SQUARE D	QOU115	CB3
7	1	TIMEMARK	261DT120	ALTERNATING RELAY
8	2	ACI	JR22FR	RED PILOT LIGHT
9	2	ACI	JR22P3M20B	HOA SWITCH
10	1	AC/DC	BL5-R-120	ALARM LIGHT
11	1	MARATHON	1323580	DISTRIBUTION BLOCK
12	2	REDINGTON	711-0190	ELAPSED TIME METER
13	1	DELTA	LA603	LIGHTNING ARRESTER
14	1	STOCK		GFI
15	1	MARATHON	1321570	NEUTRAL BLOCK
16	1	SSAC	FS126RC	FLASHER
17	1	ABB	OXP5X265	SHAFT
18	1	ABB	OHB65J5	HANDLE
19	1	DELTA	CA603R	SURGE CAPACITOR
20				
21				
22				
23				
24				
25				

	Drawing Title BILL OF MATERIALS						
DATE 9/27/05	REFERENCE DRAWING		NO.	REVISION-LOCATION	ECN	DATE	BY
	S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY		
Project Title DUPLEX PUMP CONTROL PANEL	COX Research and Technology, Inc.				P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER	
						DRAWING NUMBER CP-2138	
						SHEET NUMBER 5	