
COX

Research and Technology, Inc.

SIMPLEX PUMP CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

VOLTAGE	230V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	1	
HP	7.5	
FLA	20.4	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		


CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Timer	(Floats, Bubbler, Other)
CAPACITORS		(Yes, No)
CAPACITOR WIRING FIGURE		
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN		(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER		
ELAPSED TIME METER		
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		


SOLD TO: DELTA PROCESS EQUIPMENT
TAG : PLAIN DEALINGS

SHIP TO: DELTA PROCESS, RUSTON, LA

Drawing Title									
PANEL DESCRIPTION									
		REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	
		DATE		DATE		BY		BY	
DATE 5/12/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL		APPROVED BY		DATE
Project Title		<div style="text-align: center;">  Research and Technology, Inc. </div>				P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
SIMPLEX PUMP CONTROL PANEL						Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1564	
								SHEET NUMBER 1	




	Drawing Title							
	POWER DIAGRAM							
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
5/12/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED		
	Project Title				PURCHASE ORDER NUMBER			
	SIMPLEX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809	DRAWING NUMBER CP-1564		
					Ph. (225)756-3271 Fax (225)756-1030	SHEET NUMBER		2



* REMOVE JUMPER IF MOTOR INTERLOCKING
DEVICE IS USED.

	Drawing Title						
	CONTROL DIAGRAM						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
5/12/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED	
	Project Title				PURCHASE ORDER NUMBER		
	SIMPLEX PUMP CONTROL PANEL	<div> <div>COX</div> <div>Research and Technology, Inc.</div> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1564	
					SHEET NUMBER		3



VIEW OF FRONT OF PANEL

NOTE:

SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1 RUN
NP-2 OFF-AUTO

	Drawing Title						
	ENCLOSURE						
DATE 5/12/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	DRAWN BY C. RACHAL			APPROVED BY DATE		
	SIMPLEX PUMP CONTROL PANEL	PURCHASE ORDER NUMBER					
		DRAWING NUMBER CP-1564					
		SHEET NUMBER 4					

CB1

5

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	VYNCKIER	VJ1614HPL	ENCLOSURE
1a	1	VYNCKIER	BP1614AL	BACKPLATE
2	1	ABB	A26-30-10-84	MOTOR STARTER
3	1	ABB	TA25DU25	O.L. RELAY (18-25A)
4	1	ABB	OT63E3	DISCONNECT SWITCH
5	1	SQUARE D	QOU345	CIRCUIT BREAKER
6	1	ACI	JR22FR	RED PIOLT LIGHT
7	1	ACI	JR22P2M11B1	OFF-ON
8	1	INGRAM	MX-15	ALARM LIGHT
9	1	GRASSLIN	FM-1/STUZH-L	CLOCK
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	<h3 style="margin: 0;">BILL OF MATERIALS</h3>						
DATE 5/12/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
		COX Research and Technology, Inc.		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1564 SHEET NUMBER 6	
	Project Title	COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		
	<h3 style="margin: 0;">SIMPLEX PUMP CONTROL PANEL</h3>						