



PUMP 1 [FS3 TO BE INSTALLED IN HOT "H" LEG (FROM TERM. 10)]
 PUMP 2 [FS4 TO BE INSTALLED IN HOT "H" LEG (FROM TERM. 13)]

1	2	3	4	5	6	7	8	9	10	11	12	13	14
---	---	---	---	---	---	---	---	---	----	----	----	----	----

COMPRESSOR 1
 COMPRESSOR 2
 N
 H
 N
 H
 N
 H
 N
 H
 N
 H
 N
 H
 N
 SOURCE

FS-1 HIGH LEVEL TREATMENT PLANT MERCURY OR MECHANICAL FLOAT SWITCH
 FS-2 HIGH LEVEL DOSING TANK MECHANICAL FLOAT SWITCH
 FS-3,4 MECHANICAL FLOAT SWITCH IN DOSING TANK
 (MUST CARRY PUMP CURRENT)

* DIVERSIFIED ALTERNATOR