
COX

Research and Technology, Inc.

DUPLEX PUMP CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-1535

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	15	
FLA	52	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	Meyers	
CATALOG NUMBER	4VH150N4-23	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X - SIDE	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.	GFI Receptacle	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION	X	


SOLD TO: Delta Process - Bossier City, LA
TAG : The Colony

SHIP TO: Delta Process - Bossier City, LA


	Drawing Title						
	PANEL DESCRIPTION						
DATE 3/4/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1535
							SHEET NUMBER 1



	Drawing Title							
	POWER DIAGRAM							
DATE 3/4/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
	Project Title	COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030	PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-1535		
						SHEET NUMBER 2		



Drawing Title									
CONTROL DIAGRAM									
DATE 3/4/03	REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE	BY
	S/N		Sales Engineer C.C.		Application Engineer R.C.		DRAWN BY C. RACHAL		APPROVED BY DATE
Project Title								PURCHASE ORDER NUMBER	
DUPLIX PUMP CONTROL PANEL								DRAWING NUMBER CP-1535	
								SHEET NUMBER 3	



NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL
NP-9	HIGH TEMP
NP-10	HIGH TEMP

Drawing Title							
ENCLOSURE							
DATE	3/4/03	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED
			C.C.	R.C.	BY C. RACHAL		BY DATE
Project Title					PURCHASE ORDER NUMBER		
DUPLEX PUMP CONTROL PANEL		<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		
					DRAWING NUMBER CP-1535		
					SHEET NUMBER 4		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	ALLIED	AM24200RL	ENCLOSURE
1a	1	ALLIED	P2420	BACKPLATE
1b	1	ALLIED	HFP-2420	DEAD FRONT
2	1	MARATHON	132 3570	DISTRIBUTION BLOCK
3	2	ABB	A63-30-11-84	MOTOR STARTER
4	2	ABB	TA75DU63	O.L. RELAY (45-63A)
5	2	SQUARE D	QOU390	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	4	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22FY	AMBER PILOT LIGHT
9	2	ACI	JR22P3M20B	HOA SWITCH
10	1	MICRO STROBE	495 S-120	ALARM LIGHT
11	1	C-H	CHSA03	LIGHTNING ARRESTER
12	1	SSAC	PLMU-11	PHASE MONITOR
13	2	GRASSLIN	UWZ52E	ELAPSED TIME METER
14	2	SSAC	LLC54AA	SEAL FAIL RELAY
15	1	SQUARE D	QOU120	CB3
16	6	OMRON	G2R2SAC120	CR1-6
17				
18				
19				
20				
21				
22				
23				
24				

	Drawing Title						
	BILL OF MATERIALS						
DATE 3/4/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1535 SHEET NUMBER 5
	DUPLEX PUMP CONTROL PANEL						