

COMPRESSOR CLOCK

VACATION SWITCH

HOA SWITCH/  
MOTOR CONTACTOR.  
SPRING RETURN  
FROM HAND.


MANUAL FLUSH  
SWITCH.  
SPRING RETURN  
FROM FLUSH.

ALARM LIGHT

AUDIBLE ALARM/  
SILENCE SWITCH

ALARM PUSH TO TEST

\* JUMPERS



ADD JUMPERS FOR  
2 FLOAT SYSTEM ONLY

FILTER FLUSH VALVE

FIELD FLUSH VALVE

COMPRESSOR

PUMP  
MAX 12 AMPS

INTERNAL PUMP THERMAL  
OVERLOAD IS REQUIRED

PROGRAM 8000 R2

	Drawing Title							
	CONTROL DIAGRAM							
DATE 10/25/05		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED	
					BY C. RACHAL		BY	DATE
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	FILTER CONTROL PANEL SCHEMATIC DIAGRAM SINGLE CIRCUIT, 120VAC, SIMPLEX	COX  Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-2192		
						SHEET NUMBER 1		