
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
BAILEY BLUFF

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-1830r1

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	5	
FLA	39	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	BARNES	
CATALOG NUMBER	SGVF5022L-MS	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	Yes	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:


SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS	X	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		

SOLD TO: Delta Process - Bossier City, LA


TAG : BAILEY BLUFF

SHIP TO: Delta Process - Ruston, LA


	Drawing Title							
	PANEL DESCRIPTION							
DATE 6/24/05			REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1830r1	
					SHEET NUMBER		1	



	Drawing Title								
	POWER DIAGRAM								
DATE 6/24/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1830r1			
						SHEET NUMBER 2			



Drawing Title							
CONTROL DIAGRAM							
DATE	6/24/05	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED
			C.C.	R.C.	BY C. RACHAL		DATE
Project Title					PURCHASE ORDER NUMBER		
DUPLIX PUMP CONTROL PANEL					DRAWING NUMBER		
					CP-1830r1		
					SHEET NUMBER		
					3		



NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

Drawing Title									
ENCLOSURE									
DATE	6/24/05	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED		
			C.C.	R.C.	BY C. RACHAL		BY	DATE	
Project Title					P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER		
DUPLX PUMP CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1830r1		
							SHEET NUMBER 4		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	1	ABB	OT100E3	MAIN DISC. SWITCH
3	2	ABB	A40-30-10-84	MOTOR STARTER
4	2	ABB	TA42DU42	O.L. RELAY (29-42A)
5	2	SQUARE D	QOU280	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	4	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	AC/DC	BL5-R-120	ALARM LIGHT
10	1	MARATHON	1323580	DISTRIBUTION BLOCK
11	2	REDINGTON	711-0190	ELAPSED TIME METER
12	1	SQUARE D	QOU115	CB3
13	1	STOCK		GFI
14	2	SSAC	LLC54AA	SEAL FAIL RELAY
15	1	DELTA	LA603	LIGHTNING ARRESTER
16	2	WWG	6X555	START RELAY
17	2	WWG	4CU58	START CAPACITOR
18	2	WWG	6X660	RUN CAPACITOR
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 6/24/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1830r1 SHEET NUMBER <div style="text-align: right;">5</div>
	DUPLEX PUMP CONTROL PANEL						