

---

---

# COX

Research and Technology, Inc.

---

---

## DUPLEX BLOWER CONTROL PANEL

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

CP-1562

VOLTAGE	240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	5	
FLA	28	
TYPE OF PUMP	Blower	(Self-Priming, Submersible)
MANUFACTURER		
CATALOG NUMBER		

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR		(Floats, Bubbler, Other)
CAPACITORS		(Yes, No)
CAPACITOR WIRING FIGURE		
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:


SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN		(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT		
LIGHT PANEL MTD		
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER		
ELAPSED TIME METER		
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION	X	

SOLD TO:	Delta Process
TAG :	Blower Control Panel

SHIP TO:	Delta Process - Denham Springs, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
5/08/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER CP-1562 SHEET NUMBER 1
	DUPLEX BLOWER CONTROL PANEL						






	Drawing Title								
	CONTROL DIAGRAM								
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
5/08/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED			
	Project Title							PURCHASE ORDER NUMBER	
	DUPLEX BLOWER CONTROL PANEL							DRAWING NUMBER CP-1562	
								SHEET NUMBER	3

**COX**

Research and Technology, Inc.


P.O. Box 77808  
Baton Rouge, LA  
70809

Ph. (225)756-3271  
Fax (225)756-1030



REMOVE JUMPERS & INSTALL  
LOCKOUT DEVICES IF REQUIRED

	Drawing Title							
	EXTERNAL CONNECTIONS							
DATE 5/08/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE	BY
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1562		
						SHEET NUMBER 4		



VIEW OF FRONT COVER

NAMEPLATE SCHEDULE

**NOTE:**  
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASSES.

NP-1	BLOWER 1
NP-2	BLOWER 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

DATE 5/08/03	Drawing Title							
	ENCLOSURE							
	Project Title		REFERENCE DRAWING		NO.	REVISION-LOCATION	ECN	DATE
			S/N	Sales Engineer	Application Engineer	DRAWN	APPROVED	
				C.C.	R.C.	BY C. RACHAL	BY	DATE
	DUPLIX BLOWER CONTROL PANEL		<div style="text-align: center;"> <b>COX</b>            Research and Technology, Inc.         </div>			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER	
						Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP-1562	
							SHEET NUMBER 5	

# BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPL	ENCLOSURE
2	1	STAHLIN	BP1816AL	BACKPLATE
3	2	ABB	A30-30-10-84	STARTER
4	2	ABB	TA25DU32	O.L. (24-32A)
5	2	SQUARE D	QOU270	CIRCUIT BREAKER 1,2
6	2	ACI	JR22P3M20B	H.O.A. SWITCH
7	1	TIMEMARK	261DT120	ALTERNATING RELAY
8	1	GRASSLIN	FM/1 STUZH-L	TIMER
9	2	ACI	JR22FR	RED PILOT LIGHT
10	1	SQUARE D	9070TF150D1	TRANSFORMER

	Drawing Title						
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>						
DATE 5/08/03		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL		APPROVED BY
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 150px;"> <h1 style="margin: 0;">COX</h1> <p style="margin: 0;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER CP-1562 SHEET NUMBER <div style="text-align: right;">6</div>
	<h2 style="margin: 0;">DUPLEX BLOWER CONTROL PANEL</h2>						