

CP1969r1
PLC PARAMETERS

<u>BLOCK</u>	<u>DESCRIPTION</u>	<u>FACTORY SETTING</u>	<u>PLC NOMENCLATURE</u>
B01	No.1	Cam no.1	---
	DAY	7 days/wk	MO-SU
	ON	8:00 am	08:00
	OFF	7:00 am	07:00
B02	No.2	Cam no.1	---
	DAY	7 days/wk	MO-SU
	ON	7:00 pm	19:00
	OFF	6:00 pm	18:00
B03	No.3	Cam no.1	---
	DAY	7 days/wk	MO-SU
	ON	12:00 midnight	00:00
	OFF	11:59 pm	23:59
B04	TH = PUMP RUN TIME	12 minutes	12:00m
	TL = PUMP OFF TIME	2 hours	02:00h

Note: Minute settings are in minutes and seconds. For example 02:00m is 2 minutes, 02:10m is 2 minutes and 10 seconds. Hour settings are in hours and minutes. For example 02:00h is 2 hours and no minutes, 02:10h is 2 hours and 10 minutes, and 00:12h is 12 minutes.

In addition to the settings above, various other parameters can be viewed as follows:

- Pump run time hours
- Pump start counts
- High level counts